Power generation products

OIL ANALYSIS REPORT

Area [85305]

200 TRETHEWEY DR TORONTO CITY OF TORONTO - 12 DIVISON EBP0A301828

Right Diesel Engine

ESSO XD-3 EXTRA 15W40 (20 LTR)

| RECOMMENDATION | Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|---|------------------|----------|---------------|-----------|-------------|-------------|-------------|
| Resample at the next service interval to monitor. | Sample Number | | Client Info | | PN0006100 | PN0004642 | PN0003240 |
| | Sample Date | | Client Info | | 30 Apr 2024 | 20 Apr 2023 | 22 Apr 2022 |
| | Machine Age | hrs | Client Info | | 0 | 270 | 257 |
| | Oil Age | hrs | Client Info | | 0 | 13 | 13 |
| | Filter Age | hrs | Client Info | | 0 | 13 | 13 |
| | Oil Changed | | Client Info | | Changed | Changed | Changed |
| | Filter Changed | | Client Info | | Changed | Changed | Changed |
| | Sample Status | | | | NORMAL | NORMAL | NORMAL |
| WEAR | Iron | ppm | ASTM D5185(m) | >100 | 2 | 2 | 2 |
| All component wear rates are normal. | Chromium | ppm | ASTM D5185(m) | >20 | 0 | 0 | 0 |
| | Nickel | ppm | ASTM D5185(m) | >4 | 0 | 0 | 0 |
| | Titanium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | Silver | ppm | ASTM D5185(m) | >3 | 0 | 0 | 0 |
| | Aluminum | ppm | ASTM D5185(m) | >20 | <1 | 2 | 2 |
| | Lead | ppm | ASTM D5185(m) | >40 | 0 | <1 | <1 |
| | Copper | ppm | ASTM D5185(m) | >330 | 2 | 2 | 2 |
| | Tin | ppm | ASTM D5185(m) | >15 | 0 | <1 | <1 |
| | Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| CONTAMINATION | Silicon | ppm | ASTM D5185(m) | >25 | 2 | 6 | 6 |
| There is no indication of any contamination in the oil. | Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| | Fuel | | WC Method | >5 | <1.0 | <1.0 | <1.0 |
| | Water | | WC Method | >0.2 | NEG | NEG | NEG |
| | Glycol | | WC Method | | NEG | NEG | NEG |
| | Soot % | % | ASTM D7844* | >3 | 0 | 0 | 0 |
| | Nitration | Abs/cm | ASTM D7624* | >20 | 4.9 | 6.6 | 7.8 |
| | Sulfation | Abs/.1mm | ASTM D7415* | | 18.1 | 18.1 | 19.3 |
| | Emulsified Water | scalar | Visual* | >0.2 | NEG | NEG | NEG |
| FLUID CONDITION | Sodium | ppm | ASTM D5185(m) | >192 | 1 | 2 | 2 |
| The condition of the oil is acceptable for the time in service. | Boron | ppm | ASTM D5185(m) | | 10 | 62 | 75 |
| | Barium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| | Molybdenum | ppm | ASTM D5185(m) | | 60 | 67 | 84 |
| | Manganese | ppm | ASTM D5185(m) | | 0 | <1 | 0 |
| | Magnesium | ppm | ASTM D5185(m) | | 920 | 188 | 28 |
| | Calcium | ppm | ASTM D5185(m) | | 1102 | 2015 | 2166 |
| | Phosphorus | ppm | ASTM D5185(m) | 1370 | 1006 | 1008 | 1034 |
| | Zinc | ppm | ASTM D5185(m) | | 1166 | 1058 | 1157 |
| | Sulfur | ppm | ASTM D5185(m) | | 2629 | 2934 | 3251 |
| | Oxidation | Abs/.1mm | ASTM D7414* | >25 | 13.5 | 14.4 | 13.6 |

Visc @ 100°C cSt


ASTM D7279(m) 15.4


Contact/Location: Brett Kinkley - POWMIS


13.7

14.5

14.0









Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. Received : PN0006100 :06 May 2024 Lab Number : 02633439 :06 May 2024 Tested ISO 17025:2017 Diagnosed Accredited Unique Number : 5774592 : 06 May 2024 - Wes Davis Laboratory Test Package : MOB 1 To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com Т: F: (905)565-8544

Contact/Location: Brett Kinkley - POWMIS Page 2 of 2