

Area Area ASCENT MCC HOLDINGS [265173]

528101930

Coolant

EXTENDED LIFE COOLANT (--- GAL)

RECOMMENDATION

The fluid is suitable for further service. Resample at the next service interval to monitor.

-		
	DD	
		ION

All metal levels are normal indicating no corrosion in the cooling system.

CONTAMINANTS


There is no indication of any contamination in the coolant.


COOLANT CONDITION

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WA0020666	WA0019046	WA0017672
Sample Date		Client Info		23 Apr 2024	14 Apr 2023	25 Mar 2022
Machine Age	hrs	Client Info		217	295	190
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
Iron	ppm	ASTM D5185(m)	>15	0	<1	<1
Aluminum	ppm	ASTM D5185(m)	>10	0	<1	2
Copper	ppm	ASTM D5185(m)	>10	4	3	2
Lead	ppm	ASTM D5185(m)	>10	0	0	<1
Tin	ppm	ASTM D5185(m)	>10	<1	1	1
Silver	ppm	ASTM D5185(m)	>10	<1	0	2
Zinc	ppm	ASTM D5185(m)	>10	2	<1	1
Calcium	ppm	ASTM D5185(m)	>100	4	6	2
Magnesium	ppm	ASTM D5185(m)	>40	1	1	1
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Coolant Appearance		Visual*	Clear	Clear	Clear	Clear
Boiling Point	°C	WC Method*		107		
Specific Gravity		ASTM D1298*		1.065	1.066	1.066
рН	Scale 0-14	ASTM D1287*	9.0	9.31	9.55	9.79
Nitrites	ppm	Alcan Test Kit*		1280	1400	2080
Reserve Alkalinity	Scale 0-20	ASTM D1121*		2.8	3.1	4.0
Percentage Glycol	%	ASTM D3321*	50	48.7	49.1	49.0
Freezing Point	°C	ASTM D3321*	-40	-35	-33	-33
Carboxylate						
Silicon	ppm	ASTM D5185(m)		22	30	45
Phosphorus	ppm	ASTM D5185(m)		15	12	64
Boron	ppm	ASTM D5185(m)		177	210	215
Molybdenum	ppm	ASTM D5185(m)		2	5	6
Sodium	ppm	ASTM D5185(m)		1713	1568	1341
Potassium	ppm	ASTM D5185(m)		716	787	735
Coolant Color		Visual*	Orange/R	Red	Orange	Red

Contact/Location: David Gilkes - HARTOR Page 1 of 2





Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA 口能 Sample No. : WA0020666 Received :06 May 2024 Lab Number : 02633689 Tested :06 May 2024 ISO 17025:2017 Accredited Laboratory Diagnosed Unique Number : 5774842 : 07 May 2024 - Kevin Marson **Test Package** : COOL (Additional Tests: GlycolType) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems 10 Diesel Drive Toronto, ON CA M8W 2T8 Contact: David Gilkes dgilkes@wajax.com T: (416)259-3281 F: (416)251-6191

Contact/Location: David Gilkes - HARTOR Page 2 of 2