



WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
[85927]
 Machine Id
1038 LORNE ST SUDBURY BELL CANADA 64-6507575

Component
Rear Diesel Engine
 Fluid
ESSO XD-3 EXTRA 15W40 (12 LTR)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0006166	PN0003787	PN0002553
Sample Date		Client Info		30 Apr 2024	28 Jul 2022	28 Jun 2021
Machine Age	hrs	Client Info		262	235	214
Oil Age	hrs	Client Info		235	0	44
Filter Age	hrs	Client Info		235	0	44
Oil Changed		Client Info		Changed	Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>250	2	2	4
Chromium	ppm	ASTM D5185(m)	>10	0	0	<1
Nickel	ppm	ASTM D5185(m)	>5	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>3	0	0	<1
Aluminum	ppm	ASTM D5185(m)	>35	1	2	<1
Lead	ppm	ASTM D5185(m)	>100	0	<1	<1
Copper	ppm	ASTM D5185(m)	>60	<1	<1	2
Tin	ppm	ASTM D5185(m)	>5	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0

CONTAMINATION












Tests indicate that there is no fuel present in the oil. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>35	<1	5	6
Potassium	ppm	ASTM D5185(m)	>20	1	<1	<1
Fuel	%	ASTM D7593*	>5	0.0	<1.0	0.1
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	4.0	4.1	5.1
Sulfation	Abs/.1mm	ASTM D7415*	>30	13.9	14.1	21.0
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG

FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>192	1	3	3
Boron	ppm	ASTM D5185(m)		29	72	56
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		15	76	41
Manganese	ppm	ASTM D5185(m)		0	<1	<1
Magnesium	ppm	ASTM D5185(m)		46	112	527
Calcium	ppm	ASTM D5185(m)	3780	2470	2157	1605
Phosphorus	ppm	ASTM D5185(m)	1370	1030	961	778
Zinc	ppm	ASTM D5185(m)	1500	1167	1093	881
Sulfur	ppm	ASTM D5185(m)	3800	2727	3097	2181
Oxidation	Abs/.1mm	ASTM D7414*	>25	8.1	8.1	19.6
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	12.8	14.0	12.9



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PN0006166 **Received** : 07 May 2024
Lab Number : 02633792 **Tested** : 08 May 2024
Unique Number : 5774945 **Diagnosed** : 08 May 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.
 1050 JAYSON COURT
 MISSISSAUGA, ON
 CA L4W 2V5
 Contact: Ryan Udall
 rudall@pwrstn.com
 T: (905)565-1621
 F: (905)629-1499