

#### Machine Id 45 ESNA PARK MARKHAM BELL CANADA 1520413

## Left Diesel Engine

# **ESSO XD-3 EXTRA 15W40 (10 LTR)**

### RECOMMENDATION

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. No other corrective action is recommended at this time.	Sample Number		Client Info		PN0006024	PN0003471	PN0002165
	Sample Date		Client Info		01 May 2024	02 Sep 2022	31 Mar 2021
	Machine Age	hrs	Client Info		89	36	428
	Oil Age	hrs	Client Info		53	0	0
	Filter Age	hrs	Client Info		53	0	0
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185(m)	>250	5	11	42
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)	>10	0	0	1
	Nickel	ppm	ASTM D5185(m)	>5	0	0	<1
	Titanium	ppm	ASTM D5185(m)		0	<1	<1
	Silver	ppm	ASTM D5185(m)	>3	0	0	<1
	Aluminum	ppm	ASTM D5185(m)	>35	2	3	2
	Lead	ppm	ASTM D5185(m)	>100	<1	1	4
	Copper	ppm	ASTM D5185(m)	>60	2	5	19
	Tin	ppm	ASTM D5185(m)	>5	0	0	<1
	Vanadium	ppm	ASTM D5185(m)		0	0	0
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>35	2	9	17
Light fuel dilution occurring. No other contaminants were detected in the oil.	Potassium	ppm	ASTM D5185(m)	>20	1	1	6
	Fuel	%	ASTM D7593*	>5	1	1.6	1.3
	Water		WC Method	>0.2	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	5.4	3.6	7.9
	Sulfation	Abs/.1mm	ASTM D7415*	>30	16.0	11.4	18.8
	Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	4	8	19
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		35	57	9
	Barium	ppm	ASTM D5185(m)		<1	<1	2
	Molybdenum	ppm	ASTM D5185(m)		41	67	11
	Manganese	ppm	ASTM D5185(m)		2	5	22
	Magnesium	ppm	ASTM D5185(m)		224	96	322
	Calcium	ppm	ASTM D5185(m)	3780	2165	2220	2193
	Phosphorus	ppm	ASTM D5185(m)	1370	996	1070	983
	Zinc	ppm	ASTM D5185(m)	1500	1138	1121	1226
	Sulfur	ppm	ASTM D5185(m)	3800	2774	3263	3493
	Oxidation	Abs/.1mm	ASTM D7414*	>25	11.1	6.4	15.8

ASTM D7279(m) 15.4

Visc @ 100°C cSt

# CONTAMINATION


# **FLUID CONDITION**

Contact/Location: Brett Kinkley - POWMIS

12.9

12.0

11.1



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. Received : PN0006024 :07 May 2024 Lab Number : 02633805 Tested :08 May 2024 ISO 17025:2017 Accredited Unique Number : 5774958 : 08 May 2024 - Wes Davis Diagnosed Laboratory Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel) To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T: F: (905)565-8544

Contact/Location: Brett Kinkley - POWMIS Page 2 of 2