

Machine Id HOUND CHUTES 8C


Compressor

INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		WC0750957		
	Sample Date		Client Info		16 Jan 2024		
	Machine Age	yrs	Client Info		1		
	Oil Age	yrs	Client Info		1		
	Filter Age	yrs	Client Info		1		
	Oil Changed		Client Info		Changed		
	Filter Changed		Client Info		Changed		
	Sample Status				NORMAL		
NEAR	PQ		ASTM D8184*		0		
All component wear rates are normal.	Iron	ppm	ASTM D5185(m)	>50	0		
	Chromium	ppm	ASTM D5185(m)	>10	0		
	Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)	>25	0		
	Lead	ppm	ASTM D5185(m)	>25	0		
	Copper	ppm	ASTM D5185(m)	>50	0		
	Tin	ppm	ASTM D5185(m)	>15	0		
	Vanadium	ppm	ASTM D5185(m)		0		
	White Metal	scalar	Visual*	NONE	NONE		
	Yellow Metal	scalar	Visual*	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>25	2		
The water content is negligible. There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1		
	Water	%	ASTM D6304*	>0.1	0.168		
	ppm Water	ppm	ASTM D6304*	>1000	1690		
	Silt	scalar	Visual*	NONE	NONE		
	Debris	scalar	Visual*	NONE	NONE		
	Sand/Dirt	scalar	Visual*	NONE	NONE		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
	Emulsified Water	scalar	Visual*	>0.1	NEG		
FLUID CONDITION The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Sodium	ppm	ASTM D5185(m)		19		
	Boron	ppm	ASTM D5185(m)	0	<1		
	Barium	ppm	ASTM D5185(m)		516		
	Molybdenum	ppm	ASTM D5185(m)		0		
	Manganese	ppm	ASTM D5185(m)		0		
	Magnesium	ppm	ASTM D5185(m)	0	<1		
	Calcium	ppm	ASTM D5185(m)		2		
	Phosphorus	ppm	ASTM D5185(m)	20	2		
	Zinc	ppm	ASTM D5185(m)	0	8		
	Zinc Sulfur	ppm ppm	ASTM D5185(m) ASTM D5185(m)		8 260		
		ppm					

Visc @ 40°C cSt ASTM D7279(m) 49.4

50.3



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Ontario Power Generation** CALA Sample No. DYMOND WORK CENTRE, R.R. # 1, HWY #65 W : WC0750957 Received : 13 May 2024 Lab Number Tested : 14 May 2024 NEW LISKEARD, ON : 02634947 ISO 17025:2017 Accredited Unique Number : 5776100 : 14 May 2024 - Kevin Marson CA P0J 1P0 Diagnosed Laboratory Test Package : IND 2 (Additional Tests: KF) Contact: William Olsen To discuss this sample report, contact Customer Service at 1-800-268-2131. wd.olsen@opg.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (705)648-6102 F: (705)647-7613 Validity of results and interpretation are based on the sample and information as supplied.