



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	ABNORMAL

Machine Id
HEADWORKS GANTRY CRANE DS BRIDGE DRIVE

Component
Gearbox
Fluid
SAE 80W90 (--- GAL)

RECOMMENDATION

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

WEAR

All component wear rates are normal.








CONTAMINATION

There is no indication of any contamination in the oil.

FLUID CONDITION

Viscosity of sample indicates oil is within SAE 70W80 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0490903	---	---
Sample Date		Client Info		09 May 2024	---	---
Machine Age	yrs	Client Info		2	---	---
Oil Age	yrs	Client Info		2	---	---
Filter Age	yrs	Client Info		0	---	---
Oil Changed		Client Info		Not Changd	---	---
Filter Changed		Client Info		N/A	---	---
Sample Status				ABNORMAL	---	---
PQ		ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m)	>200	168	---	---
Chromium	ppm	ASTM D5185(m)	>15	1	---	---
Nickel	ppm	ASTM D5185(m)	>15	0	---	---
Titanium	ppm	ASTM D5185(m)		0	---	---
Silver	ppm	ASTM D5185(m)		0	---	---
Aluminum	ppm	ASTM D5185(m)	>25	5	---	---
Lead	ppm	ASTM D5185(m)	>100	88	---	---
Copper	ppm	ASTM D5185(m)	>200	<1	---	---
Tin	ppm	ASTM D5185(m)	>25	0	---	---
Vanadium	ppm	ASTM D5185(m)		0	---	---
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Silicon	ppm	ASTM D5185(m)	>50	7	---	---
Potassium	ppm	ASTM D5185(m)	>20	<1	---	---
Water		WC Method	>0.2	NEG	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	---	---
Emulsified Water	scalar	Visual*	>0.2	NEG	---	---
Sodium	ppm	ASTM D5185(m)	>50	2	---	---
Boron	ppm	ASTM D5185(m)	200	2	---	---
Barium	ppm	ASTM D5185(m)	0	<1	---	---
Molybdenum	ppm	ASTM D5185(m)	0	0	---	---
Manganese	ppm	ASTM D5185(m)		2	---	---
Magnesium	ppm	ASTM D5185(m)	0	8	---	---
Calcium	ppm	ASTM D5185(m)	20	12	---	---
Phosphorus	ppm	ASTM D5185(m)	1000	1200	---	---
Zinc	ppm	ASTM D5185(m)	20	8	---	---
Sulfur	ppm	ASTM D5185(m)	22000	22445	---	---
Acid Number (AN)	mg KOH/g	ASTM D974*		2.04	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	135	33.1	---	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0490903
Lab Number : 02635065
Unique Number : 5776218
Test Package : IND 2
Received : 13 May 2024
Tested : 14 May 2024
Diagnosed : 15 May 2024 - Kevin Marson

Ontario Power Generation
 DYMOND WORK CENTRE, R.R. # 1, HWY #65 W
 NEW LISKEARD, ON
 CA POJ 1P0
 Contact: Aaron Brammer
 aaron.brammer@opg.com
 T: (705)648-6106
 F: (705)647-7613

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.