



POWER SYSTEMS
SYSTÈMES DE PUISSANCE

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	ABNORMAL

Area
MAHONE BAY PUBLIC WORKS [6100275061]

Machine Id
U562910K

Component
Diesel Engine

Fluid
PETRO CANADA DURON SAE 15W40 (--- GAL)

RECOMMENDATION

The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WA0020879	WA0018590	WA0015971
Sample Date		Client Info		07 May 2024	29 Dec 2022	19 Oct 2022
Machine Age	hrs	Client Info		375	272	267
Oil Age	hrs	Client Info		0	2	0
Filter Age	hrs	Client Info		0	2	0
Oil Changed		Client Info		Changed	Changed	Not Changd
Filter Changed		Client Info		Changed	Changed	Not Changd
Sample Status				ABNORMAL	SEVERE	SEVERE

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>250	3	1	2
Chromium	ppm	ASTM D5185(m)	>10	0	0	0
Nickel	ppm	ASTM D5185(m)	>5	0	<1	<1
Titanium	ppm	ASTM D5185(m)		0	<1	0
Silver	ppm	ASTM D5185(m)	>3	0	0	0
Aluminum	ppm	ASTM D5185(m)	>35	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>100	0	0	0
Copper	ppm	ASTM D5185(m)	>60	2	<1	<1
Tin	ppm	ASTM D5185(m)	>5	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
White Metal	scalar	Visual*	NONE	VLITE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---

CONTAMINATION












There is a moderate amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

Silicon	ppm	ASTM D5185(m)	>35	1	5	3
Potassium	ppm	ASTM D5185(m)	>20	<1	4	5
Fuel	%	ASTM D7593*	>5	▲ 5.8	▲ 13.2	▲ 32.5
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	6.7	5.6	5.7
Sulfation	Abs/.1mm	ASTM D7415*	>30	18.6	20.2	18.6
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG

FLUID CONDITION

Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

Sodium	ppm	ASTM D5185(m)		1	2	2
Boron	ppm	ASTM D5185(m)	1	7	153	132
Barium	ppm	ASTM D5185(m)	1	0	0	0
Molybdenum	ppm	ASTM D5185(m)	60	53	<1	<1
Manganese	ppm	ASTM D5185(m)	1	0	0	0
Magnesium	ppm	ASTM D5185(m)	1010	867	14	9
Calcium	ppm	ASTM D5185(m)	1070	1006	1947	1534
Phosphorus	ppm	ASTM D5185(m)	1150	916	902	735
Zinc	ppm	ASTM D5185(m)	1270	1094	961	725
Sulfur	ppm	ASTM D5185(m)	2060	2417	2722	2121
Oxidation	Abs/.1mm	ASTM D7414*	>25	15.1	14.6	13.4
Visc @ 100°C	cSt	ASTM D7279(m)	15.6	▲ 12.5	▲ 10.3	▲ 5.9



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0020879 **Received** : 14 May 2024
Lab Number : 02635212 **Tested** : 15 May 2024
Unique Number : 5776365 **Diagnosed** : 15 May 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: PercentFuel, Visual)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems
 70 Raddall Avenue
 Dartmouth, NS
 CA B3B 1T7
 Contact: Danelle Hoffman
 dhoffman@wajax.com
 T: (902)468-6200
 F: (902)468-3325