



OIL ANALYSIS REPORT

WEAR	ABNORMAL
CONTAMINATION	SEVERE
FLUID CONDITION	NORMAL

Area
SAB1
Machine Id
Component
SAB1 G6
Turbine Bearing
Fluid
ESSO TERESSO ISO 46 (150 LTR)

RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

WEAR

Iron ppm levels are abnormal. Lead ppm levels are noted. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion.











CONTAMINATION

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

FLUID CONDITION

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0812558	WC0642846	WC0828622
Sample Date		Client Info		15 May 2024	21 Dec 2023	27 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ATTENTION
PQ		ASTM D8184*		0	0	0
Iron	ppm	ASTM D5185(m)	>7	▲ 10	1	1
Chromium	ppm	ASTM D5185(m)	>2	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>2	0	<1	<1
Lead	ppm	ASTM D5185(m)	>33	● 11	2	1
Copper	ppm	ASTM D5185(m)	>3	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>6	<1	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
White Metal	scalar	Visual*	NONE	NONE	NONE	VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Silicon	ppm	ASTM D5185(m)	>20	<1	5	5
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	<1
Water		WC Method	>2	NEG	NEG	NEG
Particles >4µm		ASTM D7647	>10000	▲ 134041	▲ 25335	● 17888
Particles >6µm		ASTM D7647	>1300	▲ 46308	● 1527	1172
Particles >14µm		ASTM D7647	>160	▲ 554	12	8
Particles >21µm		ASTM D7647	>40	39	4	1
Particles >38µm		ASTM D7647	>10	1	1	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/17/14	▲ 24/23/16	▲ 22/18/11	● 21/17/10
Silt	scalar	Visual*	NONE	LIGHT	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	VLITE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG	NEG
Sodium	ppm	ASTM D5185(m)		1	0	0
Boron	ppm	ASTM D5185(m)	0	0	0	0
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)	0	2	0	0
Calcium	ppm	ASTM D5185(m)	0	11	<1	<1
Phosphorus	ppm	ASTM D5185(m)	2.4	2	3	4
Zinc	ppm	ASTM D5185(m)	0	2	<1	2
Sulfur	ppm	ASTM D5185(m)		616	709	678
Acid Number (AN)	mg KOH/g	ASTM D974*	0.02	0.07	0.07	0.07
Visc @ 40°C	cSt	ASTM D7279(m)	46	45.7	45.5	45.2



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0812558 **Received** : 16 May 2024
Lab Number : 02636094 **Tested** : 21 May 2024
Unique Number : 5785256 **Diagnosed** : 21 May 2024 - Kevin Marson
Test Package : IND 2 (Additional Tests: PQ, PrtCount, TAN Man)

Ontario Power Generation
 NIAGARA PLANT GROUP, 14000 NIAGARA PKWY
 NIAGARA ON THE LAKE, ON
 CA L0S 1J0
 Contact: Michael Brochu
 mike.brochu@opg.com
 T: (905)357-0322
 F: (905)374-5466

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.