WEAR CONTAMINATION FLUID CONDITION

NORMAL ABNORMAL ABNORMAL

[413143720]

1000146926 - 7380-160 (S/N G1866-1)
Component
Transformer Oil


RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Interfacial Tension result is low and is likely leading to the internal arcing. We recommend an early resample to monitor this condition.	Sample Number	OOM	Client Info	Limityton	WC0909163	WC0882004	WC0812616
	Sample Date		Client Info		14 May 2024		08 May 2023
	Machine Age	hrs	Client Info		0	0	0
	Oil Age	hrs	Client Info		0	0	0
	Filter Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	N/A	N/A
	Filter Changed		Client Info		N/A	N/A	N/A
	Sample Status				ABNORMAL	SEVERE	ABNORMA
WEAR	White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
{not applicable}	Yellow Metal		Visual*	NONE	NONE	NONE	NONE
CONTAMINATION	Water	%	ASTM D6304*	>0.02	0.025	0.015	0.027
*** PLEASE NOTE: The stop-cock leaked on the syringe and there was insufficient sample for DGA ***	ppm Water	ppm	ASTM D6304*	>200	<u> </u>	156	274.0
	DGA - H2	ppm	ASTM D3612(e)*			5	
	DGA - O2	ppm	ASTM D3612(e)*			789	
	DGA - N2 DGA - CO	ppm	ASTM D3612(e)* ASTM D3612(e)*			46253 53	
	DGA - CO2	ppm	ASTM D3612(e)*			2570	
	DGA - Methane	ppm	ASTM D3612(e)*			2	
	DGA - Acetylene		ASTM D3612(e)*			0	
	DGA - Ethylene	• • • • • • • • • • • • • • • • • • • •	ASTM D3612(e)*			7	
	DGA - Ethane	ppm	ASTM D3612(e)*			, 1025	
	DGA - Total Gas Content		ASTM D3612(e)*			50704	
	DGA - Total Combustible Gas		ASTM D3612(e)*			<u></u> 1092	
	Particles >4µm		ASTM D7647	>5000	466	85	1295
	Particles >6µm		ASTM D7647		179	50	445
	Particles >14µm		ASTM D7647	>160	18	7	28
	Particles >21µm		ASTM D7647	>40	4	2	6
	Particles >38μm		ASTM D7647	>10	0	1	1
	Particles >71μm		ASTM D7647	>3	0	0	0
	Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/15/11	14/13/10	17/16/1
	Silt	scalar	Visual*	NONE	NONE	NONE	NONE
	Debris	scalar	Visual*	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
	Appearance	scalar	Visual*	NORML	NORML	NORML	NORM
	Odor	scalar	Visual*	NORML	NORML	NORML	NORM
FLUID CONDITION	Acid Number (AN)	mg KOH/g	ASTM D974*	0.22	0.05	0.08	▲ 0.06
The condition of the transformer oil is acceptable for the time in service.	Specific Gravity		ASTM D1298 *		0.922	0.921	0.922
	Dielectric Breakdown	kV	ASTM D3612(e)*		70	52	73
	Interfacial Tension	mN/m	ASTM D071/6)*		18.02	△ 18.35	▲ 18.33

1.0

<1.5

scalar ASTM D1500*

ASTM Color





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

: WC0909163 Lab Number : 02636244 Unique Number : 5785406

To discuss this sample report, contact Customer Service at 1-800-268-2131.

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received **Tested**

Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

Diagnosed Test Package: TRF 2 (Additional Tests: PrtCount)

: 16 May 2024 : 21 May 2024

: 12 Jun 2024 - Bill Quesnel

Contact: Jakub Posluszny jakub_posluszny@cargill.com T: (519)823-5200

F: (519)823-5893

Cargill Meat Solutions

165 Dunlop Drive

Guelph, ON

CA N1L 1P4