

Limit/Abn Current

History1

History2

Machine Id **10588 KEELE ST TORONTO MAPLE PS-UNIT 2 YORK REGION 1GZ08315** Component Left Diesel Engine

Test

LIOM

Method

ESSO XD-3 EXTRA 15W40 (320 LTR)

RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using MOB 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. this testkit includes BN to determine the suitability of the oil for continued use.

WEAR

Metal levels are typical for a new component breaking in. Component wear rates appear to be normal (unconfirmed).

CONTAMINATION

Fuel content negligible. There is no indication of any contamination in the oil.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0006190		
Sample Date		Client Info		14 May 2024		
Machine Age	hrs	Client Info		418		
Oil Age	hrs	Client Info		50		
Filter Age	hrs	Client Info		50		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				ABNORMAL		
Iron	ppm	ASTM D5185(m)	>100	4		
Chromium	ppm	ASTM D5185(m)	>20	0		
Nickel	ppm	ASTM D5185(m)	>2	0		
Titanium	ppm	ASTM D5185(m)	>2	0		
Silver	ppm	ASTM D5185(m)	>2	0		
Aluminum	ppm	ASTM D5185(m)	>25	<1		
Lead	ppm	ASTM D5185(m)	>40	0		
Copper	ppm	ASTM D5185(m)	>330	4		
Tin	ppm	ASTM D5185(m)	>15	0		
Vanadium	ppm	ASTM D5185(m)		0		
Silicon	ppm	ASTM D5185(m)	>25	3		
Potassium	ppm	ASTM D5185(m)	>20	۰ ۲		
Fuel	%	ASTM D3103(III) ASTM D7593*	>5	0.3		
Water	70	WC Method	>0.2	NEG		
Glycol		WC Method	20.2	NEG		
Soot %	%	ASTM D7844*	>3	0		
Nitration	Abs/cm	ASTM D7644 ASTM D7624*	>20	5.4		
Sulfation	Abs/.1mm	ASTM D7624 ASTM D7415*		22.4		
Emulsified Water			>30			
	scalar	Visual*	>0.2	NEG		
Sodium	ppm	ASTM D5185(m)	>192	3		
Boron	ppm	ASTM D5185(m)		53		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		40		
Manganese	ppm	ASTM D5185(m)		<1		
Magnesium	ppm	ASTM D5185(m)		510		
Calcium	ppm	ASTM D5185(m)	3780	1645		
Phosphorus	ppm	ASTM D5185(m)	1370	928		
Zinc	ppm	ASTM D5185(m)	1500	1072		
Sulfur	ppm	ASTM D5185(m)	3800	2451		
Oxidation	Abs/.1mm	ASTM D7414*	>25	19.5		
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	11.1		

FLUID CONDITION

Viscosity of sample indicates oil is within SAE 30 range, advise investigate. The condition of the oil is acceptable for the time in service (unconfirmed). The condition of the oil is acceptable for the time in service.

Contact/Location: Ryan Udall - POWMIS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 POWER STATION INC. CALA Sample No. : PN0006190 Received 1050 JAYSON COURT : 21 May 2024 ĥ Lab Number : 02636562 Tested MISSISSAUGA, ON : 22 May 2024 ISO 17025:2017 Accredited Unique Number : 5785724 : 22 May 2024 - Kevin Marson Diagnosed CA L4W 2V5 Laboratory Test Package : MOB 1 (Additional Tests: FuelDilution, PercentFuel) Contact: Ryan Udall To discuss this sample report, contact Customer Service at 1-800-268-2131. rudall@pwrstn.com T: (905)565-1621 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (905)629-1499 Validity of results and interpretation are based on the sample and information as supplied.

Aav14/74

4/74