



OIL ANALYSIS REPORT

| | |
|-----------------|---------------|
| WEAR | NORMAL |
| CONTAMINATION | NORMAL |
| FLUID CONDITION | NORMAL |

Area
ALKAN AIR [53302]
 Machine Id
208B P-123256 (S/N 208B0666)
 Component
Jet Turbine
 Fluid
EASTMAN TURBO OIL 2380 (--- GAL)

RECOMMENDATION

This is a baseline read-out on the submitted sample.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number | | Client Info | | GT57830 | GT56755 | GT56756 |
| Sample Date | | Client Info | | 16 May 2024 | 15 Dec 2023 | 01 Oct 2023 |
| Machine Age | hrs | Client Info | | 1389 | 0 | 0 |
| Oil Age | hrs | Client Info | | 796 | 760 | 671 |
| Filter Age | hrs | Client Info | | 36 | 89 | 86 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Filter Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | NORMAL | --- | --- |

WEAR







| | | | | | | |
|----------|-----|---------------|----|--------------|----|----|
| Iron | ppm | ASTM D5185(m) | >8 | <1 | <1 | <1 |
| Chromium | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185(m) | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | >2 | <1 | <1 | <1 |
| Lead | ppm | ASTM D5185(m) | >3 | <1 | <1 | <1 |
| Copper | ppm | ASTM D5185(m) | >3 | 0 | <1 | <1 |

CONTAMINATION

| | | | | | | |
|-------|--|-----------|------|------------|-----|-----|
| Water | | WC Method | >0.1 | NEG | NEG | NEG |
|-------|--|-----------|------|------------|-----|-----|

FLUID CONDITION

| | | | | | | |
|------------------|----------|---------------|------|-------------|------|------|
| Magnesium | ppm | ASTM D5185(m) | 0 | 0 | 0 | 0 |
| Acid Number (AN) | mg KOH/g | ASTM D974* | 0.43 | 0.77 | 1.01 | 1.07 |
| Visc @ 40°C | cSt | ASTM D7279(m) | 24.2 | 24.1 | --- | 25.3 |



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : GT57830
Lab Number : 02637806
Unique Number : 5786968
Test Package : G331 (Additional Tests: ICP)
Received : 27 May 2024
Tested : 27 May 2024
Diagnosed : 27 May 2024 - Wes Davis

Honeywell Engines
 111 S. 34th Street, 301 Receiving, Attn: SOAP Program
 PHOENIX, AZ
 US 85034
 Contact: GARRETT

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
 F: (602)365-2676