# Honeywell

**OIL ANALYSIS REPORT** 

### WEAR ABNORMAL CONTAMINATION NORMAL FLUID CONDITION NORMAL

#### Area (C-GSAX) SUMMIT AIR CHARTERS [53303] [C-GSAX] DORNIER D228 P-33041C (S/N 8153)

1 Jet Turbine

## EASTMAN TURBO OIL 2380 (--- GAL)


#### RECOMMENDATION

This is a baseline read-out on the submitted sample.

	 -	_
	Λ	D
I V 1	А	n

CONTAMINATION
FLUID CONDITION

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		GT56047	GT57222	GT56602
Sample Date		Client Info		26 May 2024	28 Feb 2024	30 Dec 2023
Machine Age	hrs	Client Info		0	16789	16656
Oil Age	hrs	Client Info		0	262	129
Filter Age	hrs	Client Info		0	262	52
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
Iron	ppm	ASTM D5185(m)	>8	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>2	0	0	0
Nickel	ppm	ASTM D5185(m)	>2	0	0	0
Silver	ppm	ASTM D5185(m)	>2	0	0	0
Aluminum	ppm	ASTM D5185(m)	>2	<mark>▲</mark> 2	<1	1
Lead	ppm	ASTM D5185(m)	>3	<1	<1	<1
Copper	ppm	ASTM D5185(m)	>3	<1	0	0
Water		WC Method	>0.1	NEG	NEG	NEG
Magnesium	ppm	ASTM D5185(m)	0	<1	<1	<1
Acid Number (AN)	mg KOH/g	ASTM D974*	0.43	0.64	0.67	0.69
Visc @ 40°C	cSt	ASTM D7279(m)	24.2	24.9	24.4	24.9



 
 Accredited Laboratory
 Unique Number
 : 5786969
 Diagnosed
 : 27 May 2024 - Wes Davis

 Test Package
 : G331 (Additional Tests: ICP)
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :
 :

T: F: (602)365-2676

Contact: GARRETT

Contact/Location: GARRETT ? - HONPHO Page 2 of 2