



OIL ANALYSIS REPORT

WEAR	SEVERE
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
Unit #3, West FD Fan In Board (S/N 8393)
 Component
Inboard Bearing
 Fluid
PETRO CANADA HYDREX AW 68 (15 LTR)

RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0927093	WC0805103	WC0677241
Sample Date		Client Info		15 May 2024	12 Dec 2023	28 Nov 2022
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		2820	0	0
Filter Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	SEVERE	SEVERE

WEAR

Iron and lead ppm levels are severe. Copper ppm levels are abnormal. Antimony ppm levels are noted. Bearing wear is indicated. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion.

Test	UOM	Method	Limit/Abn	Current	History1	History2
PQ		ASTM D8184*		37	▲ 94	8
Iron	ppm	ASTM D5185(m)	>20	▲ 76	▲ 101	▲ 130
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	3
Titanium	ppm	ASTM D5185(m)		0	0	<1
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	3	5	▲ 22
Lead	ppm	ASTM D5185(m)	>20	▲ 117	▲ 97	▲ 391
Copper	ppm	ASTM D5185(m)	>20	▲ 35	17	▲ 24
Tin	ppm	ASTM D5185(m)	>20	16	▲ 24	▲ 95
Vanadium	ppm	ASTM D5185(m)		0	0	2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE

CONTAMINATION














The water content is negligible. There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>15	9	9	9
Potassium	ppm	ASTM D5185(m)	>20	0	<1	2
Water	%	ASTM D6304*	>2	0.008	---	---
ppm Water	ppm	ASTM D6304*		90	---	---
Silt	scalar	Visual*	NONE	VLITE	VLITE	NONE
Debris	scalar	Visual*	NONE	VLITE	VLITE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	HAZY	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG	NEG

FLUID CONDITION

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

Sodium	ppm	ASTM D5185(m)		<1	1	2
Boron	ppm	ASTM D5185(m)	0	<1	0	<1
Barium	ppm	ASTM D5185(m)	0	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	<1
Manganese	ppm	ASTM D5185(m)	0	<1	<1	<1
Magnesium	ppm	ASTM D5185(m)	0	<1	<1	<1
Calcium	ppm	ASTM D5185(m)	50	30	36	● 2
Phosphorus	ppm	ASTM D5185(m)	330	311	325	256
Zinc	ppm	ASTM D5185(m)	430	276	351	● 127
Sulfur	ppm	ASTM D5185(m)	760	756	1115	● 3747
Acid Number (AN)	mg KOH/g	ASTM D974*	0.60	0.32	0.53	0.18
Visc @ 40°C	cSt	ASTM D7279(m)	67.4	67.5	72.1	67.0



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0927093 **Received** : 28 May 2024
Lab Number : **02638128** **Tested** : 31 May 2024
Unique Number : 5787290 **Diagnosed** : 31 May 2024 - Kevin Marson
Test Package : MOB 2 (Additional Tests: KF, PQ)

NEWFOUNDLAND & LABRADOR HYDRO
 HOLYROOD THERMAL GEN. STN., PO BOX 29, DUFFS RD
 CONCEPTION BAY, NL
 CA A0A 2R0
 Contact: Rory Tweedie
 rorytweedie@nlh.nl.ca
 T: (709)229-2764
 F: (709)229-7894

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.