



POWER SYSTEMS
SYSTÈMES DE PUISSANCE

OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area

TOWN OF PLASTER ROCK [6100214366]

Machine Id

924 942-C-1171770

Component

Diesel Engine

Fluid

DIESEL ENGINE OIL SAE 15W40 (--- GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WA0019589	WA0019022	---
Sample Date		Client Info		14 May 2024	01 Feb 2023	---
Machine Age	hrs	Client Info		71	33	---
Oil Age	hrs	Client Info		38	33	---
Filter Age	hrs	Client Info		38	33	---
Oil Changed		Client Info		Changed	Changed	---
Filter Changed		Client Info		Changed	Changed	---
Sample Status				NORMAL	NORMAL	---

WEAR

Metal levels are typical for a new component breaking in.

Iron	ppm	ASTM D5185(m)	>100	2	6	---
Chromium	ppm	ASTM D5185(m)	>20	0	0	---
Nickel	ppm	ASTM D5185(m)	>4	0	<1	---
Titanium	ppm	ASTM D5185(m)		0	<1	---
Silver	ppm	ASTM D5185(m)	>3	0	0	---
Aluminum	ppm	ASTM D5185(m)	>20	<1	2	---
Lead	ppm	ASTM D5185(m)	>40	0	2	---
Copper	ppm	ASTM D5185(m)	>330	2	7	---
Tin	ppm	ASTM D5185(m)	>15	0	<1	---
Vanadium	ppm	ASTM D5185(m)		0	0	---

CONTAMINATION











There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185(m)	>25	2	8	---
Potassium	ppm	ASTM D5185(m)	>20	0	0	---
Fuel		WC Method	>5	<1.0	<1.0	---
Water		WC Method	>0.2	NEG	NEG	---
Glycol		WC Method		NEG	NEG	---
Soot %	%	ASTM D7844*	>3	0	0	---
Nitration	Abs/cm	ASTM D7624*	>20	4.8	9.9	---
Sulfation	Abs/.1mm	ASTM D7415*	>30	17.6	16.3	---
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	---

FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185(m)	>158	1	3	---
Boron	ppm	ASTM D5185(m)	250	25	232	---
Barium	ppm	ASTM D5185(m)	10	0	0	---
Molybdenum	ppm	ASTM D5185(m)	100	53	0	---
Manganese	ppm	ASTM D5185(m)		<1	<1	---
Magnesium	ppm	ASTM D5185(m)	450	861	20	---
Calcium	ppm	ASTM D5185(m)	3000	1339	4447	---
Phosphorus	ppm	ASTM D5185(m)	1150	991	1100	---
Zinc	ppm	ASTM D5185(m)	1350	1118	1148	---
Sulfur	ppm	ASTM D5185(m)	4250	2490	2509	---
Oxidation	Abs/.1mm	ASTM D7414*	>25	11.9	9.7	---
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	14.7	13.4	---



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0019589 **Received** : 30 May 2024
Lab Number : 02638805 **Tested** : 30 May 2024
Unique Number : 5787967 **Diagnosed** : 30 May 2024 - Wes Davis
Test Package : MOB 1

Wajax Power Systems
 485 VENTURE DR
 MONCTON, NB
 CA E1H 2P4
 Contact: Doug Balsler
 dbalsler@wajax.com
 T: (506)855-5371
 F: (506)870-4448

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.