
WEAR CONTAMINATION FLUID CONDITION **NORMAL NORMAL NORMAL**

Machine Id

STONEBROOK ESTATES FLAMBOROUGH CLEARFORD CLEARFORD

Left Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		PN0006072	PN0004759	PN000350
	Sample Date		Client Info		27 May 2024	11 May 2023	03 Apr 202
	Machine Age	hrs	Client Info		48	47	47
	Oil Age	hrs	Client Info		1	0	1
	Filter Age	hrs	Client Info		1	0	1
	Oil Changed		Client Info		Changed	Changed	Changed
	Filter Changed		Client Info		Changed	Changed	Changed
	Sample Status				NORMAL	NORMAL	NORMAL
WEAR	Iron	ppm	ASTM D5185(m)	>51	10	6	72
Metal levels are typical for a new component breaking in.	Chromium	ppm	ASTM D5185(m)	>11	0	0	<1
	Nickel	ppm	ASTM D5185(m)	>5	0	0	1
	Titanium	ppm	ASTM D5185(m)		0	0	0
	Silver	ppm	ASTM D5185(m)	>3	0	0	0
	Aluminum	ppm	ASTM D5185(m)	>31	7	6	60
	Lead	ppm	ASTM D5185(m)	>26	4	2	26
	Copper	ppm	ASTM D5185(m)	>26	5	5	22
	Tin	ppm	ASTM D5185(m)	>4	0	<1	13
	Vanadium	ppm	ASTM D5185(m)		0	0	<1
CONTAMINATION	Silicon	ppm	ASTM D5185(m)	>22	6	6	23
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)	>20	<1	0	1
	Fuel		WC Method	>2.1	<1.0	<1.0	<1.0
	Water		WC Method	>0.21	NEG	NEG	NEG
	Glycol		WC Method		NEG	NEG	NEG
	Soot %	%	ASTM D7844*	>3	0	0	0
	Nitration	Abs/cm	ASTM D7624*	>20	4.4	6.8	7.5
	Sulfation	Abs/.1mm		>30	18.3	17.6	25.1
	Emulsified Water	scalar	Visual*	>0.21	NEG	NEG	NEG
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)	>192	2	2	5
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		7	74	60
	Barium	ppm	ASTM D5185(m)		0	0	0
	Molybdenum	ppm	ASTM D5185(m)		59	84	90
	Manganese	ppm	ASTM D5185(m)		<1	<1	2
	Magnesium	ppm	ASTM D5185(m)		916	32	52
	Calcium	ppm	ASTM D5185(m)		1112	2236	2419
	Phosphorus	ppm	ASTM D5185(m)	1370	1041	1080	1199
	Zinc	ppm	ASTM D5185(m)	1500	1174	1141	1299
	Sulfur	ppm	ASTM D5185(m)	3800	2660	3185	4042
	Oxidation	Abs/.1mm	ASTM D7414*	>25	12.9	12.4	16.0
	Visc @ 100°C	cSt	ASTM D7279(m)	15.4	15.0	14.5	14.1





CALA ISO 17025:2017 Accredited Laboratory

Laboratory

Sample No. : PN0006072 Lab Number : 02638821 Unique Number : 5787983 Test Package : MOB 1

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received : 30 May 2024 : 30 May 2024 **Tested**

: 30 May 2024 - Wes Davis Diagnosed

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

POWER STATION INC.

1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T:

F: (905)565-8544