# B POWER Station

OIL ANALYSIS REPORT

## [86174] 5053 SHEPPARD AVE E TORONTO TTC - SURFACE TTC - SURFACE

## Right Natural Gas Engine

## ESSO XD-3 EXTRA 15W40 (25 LTR)

R	EC	OM	ME	ND/	ΑΤΙ	ON

Resample at the next service interval to monitor.

$\mathbf{E} \mathbf{A} \mathbf{E}$	

Area

Metal levels are typical for a new component breaking in.

#### CONTAMINATION


There is no indication of any contamination in the oil.


#### FLUID CONDITION

The condition of the oil is acceptable for the time in service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PN0006111		
Sample Date		Client Info		22 May 2024		
Machine Age	hrs	Client Info		47		
Oil Age	hrs	Client Info		0		
Filter Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Filter Changed		Client Info		Changed		
Sample Status				NORMAL		
Iron	ppm	ASTM D5185(m)	>50	3		
Chromium	ppm	ASTM D5185(m)	>4	0		
Nickel	ppm	ASTM D5185(m)	>2	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>3	0		
Aluminum	ppm	ASTM D5185(m)	>9	<1		
Lead	ppm	ASTM D5185(m)	>30	1		
Copper	ppm	ASTM D5185(m)	>35	12		
Tin	ppm	ASTM D5185(m)	>4	<1		
Vanadium	ppm	ASTM D5185(m)		0		
Silicon	ppm	ASTM D5185(m)	>+100	6		
Potassium	ppm	ASTM D5185(m)	>20	2		
Water	ppin	WC Method	>0.1	2 NEG		
Soot %	%	ASTM D7844*	20.1	0		
Nitration	Abs/cm	ASTM D7624*	>20	5.1		
Sulfation	Abs/.1mm	ASTM D7415*	>30	15.0		
Emulsified Water	scalar	Visual*	>0.1	NEG		
Sodium	ppm	ASTM D5185(m)	>192	1		
Boron	ppm	ASTM D5185(m)		1		
Barium	ppm	ASTM D5185(m)		1		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)	0700	13		
Calcium	ppm	ASTM D5185(m)	3780	2127		
Phosphorus	ppm	ASTM D5185(m)	1370	773		
Zinc	ppm	ASTM D5185(m)	1500	873		
Sulfur	ppm	ASTM D5185(m)	3800	2795		
Oxidation	Abs/.1mm	ASTM D7414*	>25	8.0		
Visc @ 100°C	cSt	ASTM D7279(m)	15.4	14.1		

Contact/Location: Brett Kinkley - POWMIS Page 1 of 2







Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. Received : PN0006111 : 30 May 2024 Lab Number : 02638839 Tested : 30 May 2024 ISO 17025:2017 Accredited Laboratory Diagnosed Unique Number : 5788001 : 30 May 2024 - Wes Davis Test Package : MOB 1 To discuss this sample report, contact Customer Service at 1-800-268-2131.

POWER STATION INC. 1050 JAYSON COURT MISSISSAUGA, ON CA L4W 2V5 Contact: Brett Kinkley Bkinkley@pwrstn.com T: F: (905)565-8544

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Contact/Location: Brett Kinkley - POWMIS Page 2 of 2