



## Machine Id **TG #2 Unknown Component** IRVING D & E ISO 32 (--- GAL)

## RECO

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
This is a baseline read-out on the submitted sample.	Sample Number		Client Info		PP		
	Sample Date		Client Info		01 May 2024		
	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				NORMAL		
WEAR	White Metal	scalar	Visual*	NONE	NONE		
{not applicable}	Yellow Metal	scalar	Visual*	NONE	NONE		
CONTAMINATION	Water		WC Method		NEG		
{not applicable}	Silt	scalar	Visual*	NONE	NONE		
	Debris	scalar	Visual*	NONE	NONE		
	Sand/Dirt	scalar	Visual*	NONE	NONE		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
FLUID CONDITION	Oxidation Test (RPVOT)	minutes	ASTM D2272*	663	545		

ASTM D2272 - Rotating Pressure Vessel Oxidation Test (RPVOT) = 545 minutes.





Contact/Location: Blaine Sherwood - IRV1169STJ Page 2 of 2