
**WEAR** CONTAMINATION **FLUID CONDITION**  **NORMAL NORMAL NORMAL** 

## EQUINOX [155429]

8DM01078
Component
Diesel Engine

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) DIESEL ENGINE OIL SAE 30. Please confirm.	Sample Number		Client Info		CU0023220		
	Sample Date		Client Info		08 May 2024		
	Machine Age	hrs	Client Info		0		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				NORMAL		
WEAR	Iron	nnm	ASTM D5185(m)	>100	3		
WEAR	Chromium	ppm	ASTM D5185(m)		0		
All component wear rates are normal.	Nickel	ppm	ASTM D5185(m)		0		
	Titanium	ppm	ASTM D5185(m)		0		
	Silver	ppm	ASTM D5185(m)		0		
	Aluminum	ppm	ASTM D5185(m)		<1		
	Lead	ppm	ASTM D5185(m)		0		
	Copper	ppm	ASTM D5185(m)		8		
	Tin	ppm	, ,	>15	<1		
	Vanadium	ppm	ASTM D5185(m)		0		
	White Metal	scalar	Visual*	NONE	VLITE		
	Yellow Metal	scalar	Visual*	NONE	NONE		
CONTABINATION	0:1:		AOTA DE LOS	05			
CONTAMINATION	Silicon	ppm	ASTM D5185(m)		4		
Fuel content negligible. There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185(m)		2		
	Fuel Water	%	ASTM D7593*	>5	0.4 NEG		
	Glycol		WC Method	>0.2	NEG		
	Soot %	%	ASTM D7844*	~3	0		
	Nitration	Abs/cm	ASTM D7644*	>20	5.8		
	Sulfation	Abs/.1mm		>30	21.5		
	Silt	scalar	Visual*	NONE	NONE		
	Debris	scalar	Visual*	NONE	NONE		
	Sand/Dirt	scalar	Visual*	NONE	NONE		
	Appearance	scalar	Visual*	NORML	NORML		
	Odor	scalar	Visual*	NORML	NORML		
	<b>Emulsified Water</b>	scalar	Visual*	>0.2	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185(m)		2		
The condition of the oil is acceptable for the time in service.	Boron	ppm	ASTM D5185(m)		108		
	Barium	ppm	ASTM D5185(m)	10	0		
	Molybdenum	ppm	ASTM D5185(m)	100	33		
	Manganese	ppm	ASTM D5185(m)	150	0		
	Magnesium	ppm	ASTM D5185(m)		379		
	Calcium	ppm	ASTM D5185(m)	3000	1806		
	Phosphorus	ppm	ASTM D5185(m)		930 1057		
	Zinc	ppm	ASTM D5185(m)	1350	1057		
	Sulfur	ppm	ASTM D5185(m)		2556		
	Oxidation	Abs/.1mm	ASTM D7414*	- OF	18.4		





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No.

Lab Number : 02640712 Unique Number : 5789874

Received : CU0023220 **Tested** 

: 10 Jun 2024 : 11 Jun 2024 Diagnosed

: 11 Jun 2024 - Wes Davis Test Package: MOB 1 (Additional Tests: FuelDilution, PercentFuel, Visual)

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CUMMINS CANADA ULC - GENERATOR DIVISION 7175 PACIFIC CIRCLE MISSISSAUGA, ON CA L5T 2A5 Contact: Elisia Johnson

> elisia.johnson@cummins.com T: (905)795-0050 F: (905)795-9252

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.