

SB GEN SIEMENS Generator (S/N B0A0007) Lower Coolant

HYBRID (HOAT) COOLANT (--- GAL)

RECOMMENDATION

Drain system and refill with 50/50 premix of manufacturer recommended coolant. (Customer Sample Comment: coolant before a cleanse happened in the glycol loop)

00			0		
CO	RI	٦U	5	U	N

All metal levels are normal indicating no corrosion in the cooling system.


CONTAMINANTS


Hardness is elevated. Elevated hardness can allow scale formation that will reduce cooling system effectiveness.

COOLANT CONDITION

The pH level of this fluid is within the acceptable limits. The reserve alkalinity of this fluid is acceptable.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0932364		
Sample Date		Client Info		04 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		50		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
			. 15			
Iron	ppm	ASTM D5185(m)	>15	1		
Aluminum	ppm	ASTM D5185(m)	>10	<1		
Copper	ppm	ASTM D5185(m)	>10	<1		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	0		
Silver	ppm	ASTM D5185(m)	>10	<1		
Zinc	ppm	ASTM D5185(m)	>10	5		
Calcium	ppm	ASTM D5185(m)	>100	26		
Magnesium	ppm	ASTM D5185(m)	>40	3		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Coolant Appearance		Visual*	Clear	Clear		
Boiling Point	°C	WC Method*		106		
Specific Gravity		ASTM D1298*		1.060		
рН	Scale 0-14	ASTM D1287*		8.57		
Nitrites	ppm	Alcan Test Kit*		240		
Reserve Alkalinity	Scale 0-20	ASTM D1121*		3.3		
Percentage Glycol	%	ASTM D3321*		44.8		
Freezing Point	°C	ASTM D3321*		-29		
Carboxylate						
Silicon	ppm	ASTM D5185(m)		2		
Phosphorus	ppm	ASTM D5185(m)		6		
Boron	ppm	ASTM D5185(m)		7		
Molybdenum	ppm	ASTM D5185(m)		<1		
Sodium	ppm	ASTM D5185(m)		3921		
Potassium	ppm	ASTM D5185(m)		6		
Coolant Color		Visual*		Pink		





Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Watch Tower Bible and Tract Society of Canada CALA Sample No. : WC0932364 Received : 11 Jun 2024 13893 Highway 7 Lab Number : 02641288 Tested Georgetown, ON : 12 Jun 2024 ISO 17025:2017 Accredited Laboratory Unique Number : 5798827 : 12 Jun 2024 - Kevin Marson CA L7G 4S4 Diagnosed Test Package : COOL (Additional Tests: GlycolType) **Contact: Purchasing Department** To discuss this sample report, contact Customer Service at 1-800-268-2131. purchase.ca@jw.org T: (905)873-4101 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. F: (905)873-4508 Validity of results and interpretation are based on the sample and information as supplied.