

Machine Id #886432 Component Unknown Component Fluid {not provided} (--- GAL)

RECOMMENDATION

This is a baseline read-out on the submitted sample.


WEAR


{not applicable}

CONTAMINATION

ISO Cleanliness Code (ISO 4406:1999): 21/18/12; Cumulative particle counts $>4\mu$ m = 10170, $>6\mu$ m = 1521, $>14\mu$ m = 24, $>21\mu$ m = 13, $>38\mu$ m = 11, $>71\mu$ m = 9.

| | | | | · · · · · | | |
|-----------------|--------|--------------|-----------|-------------|----------|----------|
| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
| Sample Number | | Client Info | | WC0889961 | | |
| Sample Date | | Client Info | | 18 Jun 2024 | | |
| Machine Age | hrs | Client Info | | 0 | | |
| Oil Age | hrs | Client Info | | 0 | | |
| Filter Age | hrs | Client Info | | 0 | | |
| Oil Changed | | Client Info | | N/A | | |
| Filter Changed | | Client Info | | N/A | | |
| Sample Status | | | | NORMAL | | |
| | | Vieuel* | | NONE | | |
| White Metal | scalar | Visual* | NONE | NONE | | |
| Yellow Metal | scalar | Visual* | NONE | NONE | | |
| Water | | WC Method | | NEG | | |
| Particles >4µm | | ASTM D7647 | >5000 | 10170 | | |
| Particles >6µm | | ASTM D7647 | >1300 | 1521 | | |
| Particles >14µm | | ASTM D7647 | >160 | 24 | | |
| Particles >21µm | | ASTM D7647 | >40 | 13 | | |
| Particles >38µm | | ASTM D7647 | >10 | 11 | | |
| Particles >71µm | | ASTM D7647 | >3 | 9 | | |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 21/18/12 | | |
| Silt | scalar | Visual* | NONE | NONE | | |
| Debris | scalar | Visual* | NONE | NONE | | |
| Sand/Dirt | scalar | Visual* | NONE | NONE | | |
| Appearance | scalar | Visual* | NORML | NORML | | |
| Odor | scalar | Visual* | NORML | NORML | | |





Contact/Location: Rhona Denbok - FUCCAM Page 2 of 2