



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	ABNORMAL
FLUID CONDITION	NORMAL

Machine Id  
**333 MARKET DRIVE GEN #3**  
 Component  
**Diesel Engine**  
 Fluid  
**{not provided} (--- GAL)**

**RECOMMENDATION**

NOTE: The bottle submitted did not contain sample for testing.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>WC</b>	WC0795008	---
Sample Date		Client Info		<b>19 Mar 2024</b>	21 Mar 2023	---
Machine Age	hrs	Client Info		<b>0</b>	0	---
Oil Age	hrs	Client Info		<b>0</b>	0	---
Filter Age	hrs	Client Info		<b>0</b>	0	---
Oil Changed		Client Info		<b>N/A</b>	N/A	---
Filter Changed		Client Info		<b>N/A</b>	N/A	---
Sample Status				<b>ABNORMAL</b>	NORMAL	---

**WEAR**

{not applicable}

White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---

**CONTAMINATION**

{not applicable}

Fuel		WC Method	>5	<b>&lt;1.0</b>	0.8	---
Water		WC Method	>0.2	<b>NEG</b>	NEG	---
Glycol		WC Method		<b>NEG</b>	NEG	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>▲ NOOIL</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	---



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC  
**Lab Number** : 02643306  
**Unique Number** : 5800845  
**Test Package** : TEST

**Received** : 20 Jun 2024  
**Tested** : 21 Jun 2024  
**Diagnosed** : 21 Jun 2024 - Kevin Marson

**NORTHERN GENERATOR CO. LTD.**  
80 ASHBRIDGE CIRCLE,, UNIT #1 & 2  
WOODBIDGE, ON  
CA L4L 3R5

Contact: Selome Afework  
selome@northerngenerator.com

T: (905)264-9744  
F: (905)264-9714

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.