

UNIVERSITY OF TORONTO [156860] 25466055

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

RECOMMENDATION

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you filter this fluid before use. We recommend an early resample to monitor this condition.

CORROSION

{not applicable}


CONTAMINANTS

There is a moderate amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

FUEL CONDITION

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

| Test UOM Method Limit/Abn Current Histor | y1 History2 |
|--|-------------|
| Sample Number Client Info CU0022319 CU002 | |
| Sample Date Client Info 24 May 2024 15 Mar | 2024 |
| Machine Age hrs Client Info 0 32 | |
| Sample Status ABNORMAL SEVE | RE |
| · · · · · · · · · · · · · · · · · · · | |
| Aluminum ppm ASTM D5185(m) <0.1 | |
| Nickel ppm ASTM D5185(m) <0.1 | |
| Lead ppm ASTM D5185(m) <0.1 | |
| Vanadium ppm ASTM D5185(m) <0.1 | |
| Iron ppm ASTM D5185(m) <0.1 0 0 | |
| Silicon ppm ASTM D5185(m) <1.0 0 0 | |
| Sodium ppm ASTM D5185(m) <1.0 | |
| Potassium ppm ASTM D5185(m) <0.1 | |
| Water % ASTM D6304* <0.05 | |
| ppm Water ppm ASTM D6304* <500 0 46 | |
| Particles >4µm ASTM D7647 >2500 ▲ 13418 115 | 9.3 |
| Particles >6µm ASTM D7647 >640 ▲ 4735 244 | |
| Particles >14µm ASTM D7647 >80 A 349 10 | |
| Particles >21µm ASTM D7647 >20 A 79 2 | |
| Particles >38μm ASTM D7647 >4 7 0 | |
| Particles >71µm ASTM D7647 >3 1 0 | |
| | 15/10 |
| Calcium ppm ASTM D5185(m) <0.1 | |
| Magnesium ppm ASTM D5185(m) <0.1 0 0 | |
| Phosphorus ppm ASTM D5185(m) <0.1 | |
| Zinc ppm ASTM D5185(m) <0.1 0 0 | |
| | |
| Specific Gravity ASTM D1298* 0.839 0.843 0.8 | 41 |
| Fuel Color text Visual Screen* Yllow Orang Re | d |
| Visc @ 40°C cSt ASTM D7279(m) 3.0 2.5 2.4 | |
| Pensky-Martens Flash Point °C ASTM D7215* 52 🔺 23 | |
| Sulfur ppm ASTM D5185(m) 10 9 10 | |
| Initial Boiling Point °C ASTM D2887* 165 148 144 | 4 |
| 10% Distill Point °C ASTM D2887* 201 201 199 | |
| 20% Distill Point °C ASTM D2887* 216 219 217 | 7 |
| 30% Distill Point °C ASTM D2887* 230 235 233 | |
| 40% Distill Point °C ASTM D2887* 243 249 247 | 7 |
| 50% Distill Point °C ASTM D2887* 255 263 260 |) |
| 60% Distill Point °C ASTM D2887* 267 276 274 | 4 |
| 70% Distill Point °C ASTM D2887* 280 290 288 | 3 |
| 80% Distill Point °C ASTM D2887* 295 307 304 | 4 |
| 90% Distill Point °C ASTM D2887* 310 329 323 | 3 |
| Final Boiling Point °C ASTM D2887* 341 379 354 | 4 |
| API Gravity ASTM D1298* 37.7 36 36 | |
| Cetane Index ASTM D4737* <40.0 | |



CUMMINS CANADA ULC - GENERATOR DIVISION Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CALA Sample No. : CU0022319 Received : 21 Jun 2024 7175 PACIFIC CIRCLE Lab Number : 02643562 Tested MISSISSAUGA, ON : 27 Jun 2024 ISO 17025:2017 Accredited : 27 Jun 2024 - Kevin Marson CA L5T 2A5 Unique Number : 5801101 Diagnosed Laboratory Test Package : FUEL (Additional Tests: CC Flash, PrtCount) Contact: Elisia Johnson To discuss this sample report, contact Customer Service at 1-800-268-2131. elisia.johnson@cummins.com Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (905)795-0050 F: (905)795-9252 Validity of results and interpretation are based on the sample and information as supplied.

Contact/Location: Elisia Johnson - CUMMISGEN Page 2 of 2