



POWER SYSTEMS
SYSTÈMES DE PUISSANCE

OIL ANALYSIS REPORT

| | |
|-----------------|-----------------|
| WEAR | NORMAL |
| CONTAMINATION | SEVERE |
| FLUID CONDITION | ABNORMAL |

Area
SHERBOURNE HEALTH [297824]

Machine Id
5312002415

Component
Diesel Engine

Fluid
CASTROL 15W40 (--- GAL)

RECOMMENDATION

We advise that you check the fuel injection system. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. Please specify the component make and model with your next sample.

| Test | UOM | Method | Limit/Abn | Current | History1 | History2 |
|----------------|-----|-------------|-----------|--------------------|-------------|-------------|
| Sample Number | | Client Info | | WA0018235 | WA0020297 | WA0019558 |
| Sample Date | | Client Info | | 10 Jun 2024 | 17 Aug 2023 | 16 May 2023 |
| Machine Age | hrs | Client Info | | 294 | 274 | 267 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Filter Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | Changed | Changed | Changed |
| Filter Changed | | Client Info | | Changed | Changed | Changed |
| Sample Status | | | | SEVERE | MARGINAL | ABNORMAL |

WEAR

Metal levels are typical for a new component breaking in.

| | | | | | | |
|----------|-----|---------------|------|--------------|----|----|
| Iron | ppm | ASTM D5185(m) | >100 | 2 | 2 | 2 |
| Chromium | ppm | ASTM D5185(m) | >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >4 | <1 | <1 | 0 |
| Titanium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| Silver | ppm | ASTM D5185(m) | >3 | 0 | <1 | 4 |
| Aluminum | ppm | ASTM D5185(m) | >20 | 1 | <1 | <1 |
| Lead | ppm | ASTM D5185(m) | >40 | 0 | <1 | <1 |
| Copper | ppm | ASTM D5185(m) | >330 | <1 | 1 | <1 |
| Tin | ppm | ASTM D5185(m) | >15 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |

CONTAMINATION












There is a high amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

| | | | | | | |
|------------------|----------|---------------|------|--------------|-------|-------|
| Silicon | ppm | ASTM D5185(m) | >25 | 2 | 3 | 3 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | <1 |
| Fuel | % | ASTM D7593* | >5 | ▲ 8 | ▲ 3.6 | ▲ 7.7 |
| Water | | WC Method | >0.2 | NEG | NEG | NEG |
| Glycol | | WC Method | | NEG | NEG | NEG |
| Soot % | % | ASTM D7844* | >3 | 0 | 0 | 0 |
| Nitration | Abs/cm | ASTM D7624* | >20 | 6.2 | 5.6 | 5.6 |
| Sulfation | Abs/.1mm | ASTM D7415* | >30 | 15.8 | 17.2 | 16.3 |
| Emulsified Water | scalar | Visual* | >0.2 | NEG | NEG | NEG |

FLUID CONDITION

Fuel is present in the oil and is lowering the viscosity. The oil is no longer serviceable due to the presence of contaminants.

| | | | | | | |
|--------------|----------|---------------|------|---------------|------|--------|
| Sodium | ppm | ASTM D5185(m) | | 2 | 1 | 2 |
| Boron | ppm | ASTM D5185(m) | | 6 | 7 | 12 |
| Barium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185(m) | | 4 | 4 | 1 |
| Manganese | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Magnesium | ppm | ASTM D5185(m) | | 66 | 71 | 26 |
| Calcium | ppm | ASTM D5185(m) | 3200 | 2053 | 2204 | 2253 |
| Phosphorus | ppm | ASTM D5185(m) | 900 | 818 | 957 | 950 |
| Zinc | ppm | ASTM D5185(m) | 1000 | 970 | 1006 | 984 |
| Sulfur | ppm | ASTM D5185(m) | | 2892 | 3104 | 3155 |
| Oxidation | Abs/.1mm | ASTM D7414* | >25 | 9.9 | 9.8 | 10.4 |
| Visc @ 100°C | cSt | ASTM D7279(m) | 17.3 | ▲ 11.7 | 13.5 | ▲ 12.0 |



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0018235 **Received** : 03 Jul 2024
Lab Number : 02645161 **Tested** : 05 Jul 2024
Unique Number : 5802700 **Diagnosed** : 05 Jul 2024 - Wes Davis
Test Package : MOB 1 (Additional Tests: FUELDILUTION, PercentFuel)

Wajax Power Systems
 10 Diesel Drive
 Toronto, ON
 CA M8W 2T8
 Contact: David Gilkes
 dgilkes@wajax.com
 T: (416)259-3281
 F: (416)251-6191

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.