



COOLANT REPORT

CORROSION

NORMAL

CONTAMINANTS

NORMAL

COOLANT CONDITION

NORMAL

Area

[PMIAS2133091]

Machine Id

QT15068KNAN 4699640

Component

Coolant

Fluid

{not provided} (--- QTS)

RECOMMENDATION

The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0022424	---	---
Sample Date		Client Info		09 Sep 2022	---	---
Machine Age	hrs	Client Info		445	---	---
Oil Age	hrs	Client Info		0	---	---
Oil Changed		Client Info		N/A	---	---
Sample Status				NORMAL	---	---







CORROSION

Total Dissolved Solids				241.0	---	---
Coolant Appearance		*Visual	Clear	normal	---	---

CONTAMINANTS

There is no indication of any contamination in the coolant.

Specific Gravity		*ASTM D1298		1.064	---	---
pH	Scale 0-14	ASTM D1287		9.76	---	---
Nitrites	ppm	AP-053:2009		1576	---	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		47.3	---	---
Freezing Point	°F	ASTM D3321		-28	---	---
Carboxylate				n/a	---	---
Coolant Color		*Visual		Pink	---	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0022424
Lab Number : 05646842
Unique Number : 10141381
Test Package : COOL- (Additional Tests: COOL)

Received : 20 Sep 2022
Tested : 26 Sep 2022
Diagnosed : 26 Sep 2022 - Jonathan Hester

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736

Contact: LESLIE SNURR
 LSNURR@KGE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (410)257-5225
 F: (410)257-5227