
**WEAR** CONTAMINATION **FLUID CONDITION** 

**ABNORMAL** NORMAL **NORMAL** 

## Leroi Air Compressor # 2 (S/N 422GX259)

Component Air Compressor

GARDNER DENVER AEON 9000 SP ( GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor.	Sample Number		Client Info		WC0718300	WC0491530	
	Sample Date		Client Info		10 Oct 2022	21 Jan 2021	
	Machine Age	hrs	Client Info		0	0	
	Oil Age	hrs	Client Info		0	0	
	Filter Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		N/A	N/A	
	Filter Changed		Client Info		N/A	N/A	
	Sample Status				ABNORMAL	NORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	2	1	
The copper level is abnormal. All other component wear rates are normal.	Chromium	ppm	ASTM D5185m	>4	0	0	
	Nickel	ppm	ASTM D5185m	>4	0	<1	
	Titanium	ppm	ASTM D5185m		0	0	
	Silver	ppm	ASTM D5185m		0	<1	
	Aluminum	ppm	ASTM D5185m	>10	0	0	
	Lead	ppm	ASTM D5185m	>20	0	<1	
	Copper	ppm	ASTM D5185m	>40	<u></u> 50	8	
	Tin	ppm	ASTM D5185m	>5	0	0	
	Vanadium	ppm	ASTM D5185m		0	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	<1	<1	
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1	1	
	Water		WC Method	>0.6	NEG	NEG	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	LIGHT	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0	31	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0	0	<1	
	Barium	ppm	ASTM D5185m	0	1	0	
	Molybdenum	ppm	ASTM D5185m	0	0	0	
	Manganese	ppm	ASTM D5185m		0	<1	
	Magnesium	ppm	ASTM D5185m	0	<1	11	
	Calcium	ppm	ASTM D5185m		0	19	
	Phosphorus	ppm	ASTM D5185m		329	577	
	Zinc	ppm	ASTM D5185m		38	67	
	Sulfur	ppm	ASTM D5185m		1407	266	
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.30	0.271	
	Visc @ 40°C	cSt	ASTM D445	49.01	51.7	47.6	







Certificate L2367

Laboratory Sample No.

: WC0718300 Lab Number : 05671712 Unique Number : 10181282 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 20 Oct 2022 **Tested** : 24 Oct 2022

Diagnosed

: 24 Oct 2022 - Doug Bogart To discuss this sample report, contact Customer Service at 1-800-237-1369.

US 45895 Contact: Ines Koschalk ikoschalk@amtrim.com T: (419)739-4336

**AMERICAN TRIM** 

WAPAKONETA, OH

317 KREIN AVE

F: (419)739-4374

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)