



FUEL REPORT

CORROSION	NORMAL
CONTAMINANTS	ATTENTION
FUEL CONDITION	NORMAL

Machine Id
DUKE HOSP ALBERT EYE 4000 GAL

Component
Diesel Fuel

Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

RECOMMENDATION

All other laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC05687544	WC04583515	---
Sample Date		Client Info		07 Nov 2022	31 Oct 2018	---
Machine Age	hrs	Client Info		0	0	---
Sample Status				ATTENTION	NORMAL	---

CORROSION

All metal levels are normal indicating no corrosion in the system.

Aluminum	ppm	ASTM D5185m	<0.1	0	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	0	---
Lead	ppm	ASTM D5185m	<0.1	0	<1	---
Vanadium	ppm	ASTM D5185m	<0.1	0	0	---
Iron	ppm	ASTM D5185m	<0.1	0	<1	---

CONTAMINANTS








There is a moderate amount of silt (particulates < 14 microns in size) present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Silicon	ppm	ASTM D5185m	<1.0	0	<1	---
Sodium	ppm	ASTM D5185m	<0.1	0	0	---
Potassium	ppm	ASTM D5185m	<0.1	0	0	---
Water	%	ASTM D6304	<0.05	0.005	0.007	---
ppm Water	ppm	ASTM D6304	<500	56.6	70	---
Particles >4µm		ASTM D7647		5606	---	---
Particles >6µm		ASTM D7647	>640	1056	---	---
Particles >14µm		ASTM D7647	>80	31	---	---
Particles >21µm		ASTM D7647	>20	5	---	---
Particles >38µm		ASTM D7647	>4	0	---	---
Particles >71µm		ASTM D7647	>3	0	---	---
Oil Cleanliness		ISO 4406 (c)	>-/16/13	20/17/12	---	---
% Gasoline	%	*In-House	<0.50	0.0	0.0	---
% Biodiesel	%	*In-House	<20.0	0.0	0.7	---
Calcium	ppm	ASTM D5185m	<0.1	3	0	---
Magnesium	ppm	ASTM D5185m	<0.1	0	0	---
Phosphorus	ppm	ASTM D5185m	<0.1	2	<1	---
Zinc	ppm	ASTM D5185m	<0.1	0	0	---

FUEL CONDITION

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

Specific Gravity		*ASTM D1298	0.839	0.842	0.843	---
Fuel Color	text	*Visual Screen	Yllow	Red	Red	---
ASTM Color	scalar	*ASTM D1500		L4.0	L5.5	---
Visc @ 40°C	cSt	ASTM D445	3.0	2.53	2.49	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	68	62	---
Sulfur	ppm	ASTM D5185m	10	0	7	---
Sulfur (UVF)	ppm	ASTM D5453		13	13	---
Initial Boiling Point	°C	ASTM D86	165	172	166	---
10% Distill Point	°C	ASTM D86	201	204	202	---
20% Distill Point	°C	ASTM D86	216	218	218	---
30% Distill Point	°C	ASTM D86	230	233	231	---
40% Distill Point	°C	ASTM D86	243	246	245	---
50% Distill Point	°C	ASTM D86	255	259	259	---
60% Distill Point	°C	ASTM D86	267	273	273	---
70% Distill Point	°C	ASTM D86	280	288	288	---
80% Distill Point	°C	ASTM D86	295	305	305	---
90% Distill Point	°C	ASTM D86	310	326	326	---
Final Boiling Point	°C	ASTM D86	341	349	352	---
Distillation Residue	%	ASTM D86	3.0	1.4	1.4	---
Distillation Loss	%	ASTM D86	3.0	0.9	0.8	---
API Gravity		ASTM D7777	37.7	36.6	36.4	---
Cetane Index		ASTM D4737	<40.0	47.9	47.2	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC05687544
Lab Number : 05687544
Unique Number : 10207116
Test Package : DF-2 (Additional Tests: Screen)

Received : 07 Nov 2022
Tested : 11 Nov 2022
Diagnosed : 17 Nov 2022 - Doug Bogart

COUCH OIL COMPANY
 2907 HILLSBOROUGH RD
 DURHAM, NC
 US 27705
 Contact: JESSE BROWN
 jesse@couchoilcompany.com
 T: (919)285-5408
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)