

WEAR NORMAL CONTAMINATION NORMAL FLUID CONDITION SEVERE

STEAM AND POWER 424.1250 # 9 AIR COMPRESSOR

Air Compressor

PENNZOIL DEXRON MERCON ATF FLUID (15 GAL)

RECOMMENDATION

Recommend drain oil if not already done and flush before refilling with oil. We recommend an early resample to monitor this condition.



All component wear rates are normal.


CONTAMINATION

The amount and size of particulates present in the system are acceptable.

FLUID CONDITION

The oil viscosity is higher than normal because of excessive oxidation. The AN level is above the recommended limit. Additives are consistent with reported ATF fluid.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		PE0000296		
Sample Date		Client Info		28 Feb 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Filter Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Filter Changed		Client Info		N/A		
Sample Status		0.101.11.10		SEVERE		
PQ		ASTM D8184		21		
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m	>4	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>40	<1		
Tin	ppm	ASTM D5185m	>5	0		
Vanadium	ppm	ASTM D5185m		0		
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Silicon	ppm	ASTM D5185m	>25	2		
Potassium	ppm	ASTM D5185m	>20	3		
Water	%	ASTM D6304	>0.6	NEG		
Particles >4µm		ASTM D7647		4369		
Particles >6µm		ASTM D7647	>2500	1148		
Particles >14µm		ASTM D7647		102		
Particles >21µm		ASTM D7647	>80	32		
Particles >38µm		ASTM D7647	>20	1		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/14		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.6	NEG		
Sodium	ppm	ASTM D5185m		51		
Boron	ppm	ASTM D5185m		28		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		96		
Phosphorus	ppm	ASTM D5185m		191		
Zinc	ppm	ASTM D5185m		42		
Sulfur	ppm	ASTM D5185m		469		
Acid Number (AN)	mg KOH/g	ASTM D8045		▲ 33.25		
Visc @ 40°C	cSt	ASTM D445	34.35	123		
_						



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 **Port Townsend Paper Corporation** Sample No. : PE0000296 Received :08 Mar 2023 100 Mill Rd Lab Number : 05786118 Tested : 13 Mar 2023 Port Townsend, WA US 98368 Unique Number : 10370789 Diagnosed : 13 Mar 2023 - Doug Bogart Test Package : PLANT (Additional Tests: ICP, KF, KV40, PQ, PrtCount, SCREEN) Contact: LONNIE LOREE Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. lonnie.loree@ptpc.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (907)738-6506 F: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)