



# OIL ANALYSIS REPORT

WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area  
**Co-Gen - Utilities**  
 Machine Id  
**40-2310 - MILL AC 4**  
 Component  
**Air Compressor**  
 Fluid  
**{not provided} (--- GAL)**

## RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>PE0000255</b>	PE0000268	---
Sample Date		Client Info		<b>21 Mar 2023</b>	03 Jan 2023	---
Machine Age	hrs	Client Info		<b>0</b>	0	---
Oil Age	hrs	Client Info		<b>0</b>	1436	---
Filter Age	hrs	Client Info		<b>0</b>	0	---
Oil Changed		Client Info		<b>N/A</b>	N/A	---
Filter Changed		Client Info		<b>N/A</b>	N/A	---
Sample Status				<b>NORMAL</b>	NORMAL	---

## WEAR

All component wear rates are normal.

PQ		ASTM D8184		<b>10</b>	12	---
Iron	ppm	ASTM D5185m	>50	<b>0</b>	<1	---
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	>4	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m		<b>0</b>	0	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	---
Lead	ppm	ASTM D5185m	>20	<b>0</b>	0	---
Copper	ppm	ASTM D5185m	>40	<b>8</b>	2	---
Tin	ppm	ASTM D5185m	>5	<b>0</b>	0	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	---
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	---

## CONTAMINATION











There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Silicon	ppm	ASTM D5185m	>25	<b>1</b>	<1	---
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	---
Water	%	ASTM D6304	>0.6	<b>NEG</b>	NEG	---
Particles >4µm		ASTM D7647	>10000	<b>6910</b>	1387	---
Particles >6µm		ASTM D7647	>2500	<b>2064</b>	480	---
Particles >14µm		ASTM D7647	>320	<b>83</b>	80	---
Particles >21µm		ASTM D7647	>80	<b>7</b>	29	---
Particles >38µm		ASTM D7647	>20	<b>0</b>	2	---
Particles >71µm		ASTM D7647	>4	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>20/18/14</b>	18/16/13	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	---
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	---
Emulsified Water	scalar	*Visual	>0.6	<b>NEG</b>	NEG	---

## FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>12</b>	33	---
Boron	ppm	ASTM D5185m		<b>28</b>	0	---
Barium	ppm	ASTM D5185m		<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m		<b>0</b>	<1	---
Manganese	ppm	ASTM D5185m		<b>0</b>	0	---
Magnesium	ppm	ASTM D5185m		<b>0</b>	1	---
Calcium	ppm	ASTM D5185m		<b>88</b>	99	---
Phosphorus	ppm	ASTM D5185m		<b>205</b>	235	---
Zinc	ppm	ASTM D5185m		<b>8</b>	21	---
Sulfur	ppm	ASTM D5185m		<b>707</b>	459	---
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.94</b>	0.79	---
Visc @ 40°C	cSt	ASTM D445		<b>28.3</b>	27.3	---



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PE0000255 **Received** : 23 Mar 2023  
**Lab Number** : 05800221 **Tested** : 24 Mar 2023  
**Unique Number** : 10389905 **Diagnosed** : 24 Mar 2023 - Doug Bogart  
**Test Package** : PLANT ( Additional Tests: ICP, KF, KV40, PQ, PrtCount, SCREEN )

**MCKINLEY PAPER COMPANY**  
 1902 MARINE DR  
 PORT ANGELES, WA  
 US 98363  
 Contact: CHAD GALLAUHER  
 chad.gallauher@biopappel.com  
 T: (360)457-4474  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)