

## WEAR NORMAL CONTAMINATION ABNORMAL FLUID CONDITION NORMAL

## Machine Id **API323-745** Component **Compressor** Fluid **PROFERMA 46 (--- GAL) RECOMMENDATION**

We recommend you service the filters on this component. Resample at the next service interval to monitor.

VV	ы

All component wear rates are normal.

## CONTAMINATION


Moderate concentration of visible dirt/debris present in the oil.

FLUID CONDITION				
		$\mathbf{c}$		
	FLU		ND	JIN

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		WC0781012	WC0781007	
Sample Date		Client Info		10 May 2023	20 Mar 2023	
Machine Age	hrs	Client Info		20884	20530	
Oil Age	hrs	Client Info		350	2281	
Filter Age	hrs	Client Info		350	2281	
Oil Changed		Client Info		Not Changd	Changed	
Filter Changed		Client Info		Not Changd	Changed	
Sample Status				ABNORMAL	NORMAL	
Iron	ppm	ASTM D5185m	>50	36	34	
Chromium	ppm	ASTM D5185m	>5	<1	<1	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		2	2	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>15	4	2	
Lead	ppm	ASTM D5185m	>65	0	0	
Copper	ppm	ASTM D5185m	>65	<1	4	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Silicon	ppm	ASTM D5185m	>35	11	14	
Potassium	ppm	ASTM D5185m	>20	4	6	
Water	ppin	WC Method	>0.1	- NEG	NEG	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE		LIGHT	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
Sodium	ppm	ASTM D5185m		5	7	
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		7	8	
Magnesium	ppm	ASTM D5185m		3	4	
Calcium	ppm	ASTM D5185m		16	14	
Phosphorus	ppm	ASTM D5185m		54	89	
Zinc	ppm	ASTM D5185m		5	39	
Sulfur	ppm	ASTM D5185m		183	341	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.226	0.11	
Visc @ 40°C	cSt	ASTM D445		46.9	47.1	

Contact/Location: Phil Shaver - CASERIPA



Sample No. : WC0781012 Recieved : 15 May 2023 2022 FILMORE AVENUE Lab Number : 05847243 : 17 May 2023 ERIE, PA Diagnosed Unique Number : 10471350 Diagnostician : Don Baldridge US 16506 Test Package : IND 2 Contact: Phil Shaver Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. pshaver@cascousa.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Contact/Location: Phil Shaver - CASERIPA

Page 2 of 2