CORROSION CONTAMINANTS COOLANT CONDITION


ABNORMAL NORMAL **NORMAL**

DAKOTA RANGE III [200006928]

20WEA87757 - D-03-A

Component Coolant

CLARIANT ANTIFROGEN N (LTR)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. We recommend an early resample to monitor this condition.	Sample Number		Client Info		NX05852695		
	Sample Date		Client Info		25 Apr 2023		
	Machine Age	hrs	Client Info		14064		
	Oil Age	hrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Sample Status				ABNORMAL		
CORROSION	Iron	ppm	ASTM D6130	>15	4 2		
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D6130	>10	8		
	Copper	ppm	ASTM D6130	>10	1		
	Lead	ppm	ASTM D6130	>10	<1		
	Tin	ppm	ASTM D6130	>10	2		
	Zinc	ppm	ASTM D6130	>10	5		
CONTAMINANTS	Calcium	ppm	ASTM D6130		<1		
There is no indication of any contamination in the coolant.	Chlorine	ppm	ASTM D6130		38		
	Magnesium	ppm	ASTM D6130		1		
	Total Dissolved Solids				282.5		
	Coolant Appearance		*Visual	Clear	normal		
COOLANT CONDITION	Specific Gravity		*ASTM D1298	1.11	1.067		
The glycol level is acceptable. The pH level of this fluid is within the acceptable limits.	рН	Scale 0-14	ASTM D1287	8.5	8.02		
	Nitrites	ppm	AP-053:2009		72		
	Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
	Percentage Glycol	%	ASTM D3321	44	50.0		
	Freezing Point	°F	ASTM D3321	-32	-35		
	Carboxylate				n/a		
	Silicon	ppm	ASTM D6130	3	10		
	Phosphorus	ppm	ASTM D6130	5	56		
	Boron	ppm	ASTM D6130	15	20		
	Molybdenum	ppm	ASTM D6130	110	306		
	Sodium	ppm	ASTM D6130	2400	5350		
	Potassium	ppm	ASTM D6130		278		
	Coolant Color		*Visual	Yellow	Yllow		







Certificate L2367

Laboratory Sample No. Unique Number : 10482050

Lab Number : 05852695

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : NX05852695

Received **Tested** Diagnosed

: 19 May 2023 : 26 May 2023

: 04 Jun 2023 - Doug Bogart

NORDEX USA - Chicago

300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL US 60606

Test Package : COOL- (Additional Tests: COOL, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: DEVIN LINEHAN DLinehan@nordex-online.com T: (312)386-4124

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (312)386-7102