
WEAR CONTAMINATION **FLUID CONDITION**

NORMAL NORMAL NORMAL

MCQUAY MCNEIL PHARM C-14119

Component Refrigeration Compressor

ICI EMKARATE RL 68H (4 GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		WC0798496		
	Sample Date		Client Info		15 May 2023		
	Machine Age	hrs	Client Info		44231		
	Oil Age	hrs	Client Info		44231		
	Filter Age	hrs	Client Info		44231		
	Oil Changed		Client Info		Not Changd		
	Filter Changed		Client Info		Not Changd		
	Sample Status				NORMAL		
WEAR	Iron	nnm	ASTM D5185m	>100	0		
WEAR	Chromium	ppm	ASTM D5185m		0		
All component wear rates are normal.	Nickel	ppm	ASTM D5185m	>10	0		
		ppm					
	Titanium Silver	ppm	ASTM D5185m ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	<u>>50</u>	0		
	Lead	ppm	ASTM D5185m		0		
		ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		0		
	Vanadium	ppm	ASTM D5185m	>10	0		
	White Metal	ppm	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE			
	reliow Metal	scalar	VISUAI	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>50	44		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1		
	Water	%	ASTM D6304	>0.02	0.009		
	ppm Water	ppm	ASTM D6304	>250	94.2		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.02	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m	0	0		
	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		0		
	Magnesium	ppm	ASTM D5185m	0	0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m	-	1		
	Zinc	ppm	ASTM D5185m		0		
	Sulfur	ppm	ASTM D5185m		70		
	Acid Number (AN)	mg KOH/g	ASTM D974		0.013		
	Visc @ 40°C	cSt	ASTM D445		60.5		
Report Id: MCQUPP [WUSCAR] 05861955 (Generated: 01/10/2024 10:09:44) Rev: 1					NDREW TU		







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: WC0798496 : 05861955 : 10496420 Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 01 Jun 2023 Diagnosed : 02 Jun 2023 Diagnostician

: Don Baldridge

DAIKIN APPLIED 5021 HOWERTON WAY SUITE P

BOWIE, MD US 20715 Contact: ANDREW TURLINGTON

andrew.turlington@daikinapplied.com T: (301)735-1440

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (301)735-1838

Contact/Location: ANDREW TURLINGTON - MCQUPP