

Machine Id **MCQUAY MCNEIL PHARM C-141150**

Component Refrigeration Compressor

ICI EMKARATE RL 68H (4 GAL)

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
Resample at the next service interval to monitor.	Sample Number		Client Info		WC0798495		
	Sample Date		Client Info		15 May 2023		
	Machine Age	hrs	Client Info		45891		
	Oil Age	hrs	Client Info		45891		
	Filter Age	hrs	Client Info		45891		
	Oil Changed		Client Info		Not Changd		
	Filter Changed		Client Info		Not Changd		
	Sample Status				NORMAL		
WEAR	Iron		ASTM D5185m	. 100	•		
WEAN	Iron	ppm			0		
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	0		
	Nickel	ppm	ASTM D5185m		0		
	Titanium	ppm	ASTM D5185m		0		
	Silver Aluminum	ppm	ASTM D5185m	. 50	0		
		ppm	ASTM D5185m		0		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		0		
	Tin	ppm	ASTM D5185m	>10	0		
	Vanadium	ppm	ASTM D5185m	NONE	0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>50	33		
There is no indication of any contamination in the oil.	Potassium	ppm	ASTM D5185m	>20	<1		
	Water	%	ASTM D6304	>0.02	0.012		
	ppm Water	ppm	ASTM D6304	>250	121.3		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	LIGHT		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.02	NEG		
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
The AN level is acceptable for this fluid. The condition of the oil is	Boron	ppm	ASTM D5185m		0		
suitable for further service.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m	0	0		
	Manganese	ppm	ASTM D5185m		0		
	Magnesium	ppm	ASTM D5185m		0		
	Calabuma	ppm	ASTM D5185m	0	0		
	Calcium						
	Phosphorus Zinc	ppm	ASTM D5185m		1 0		

Sulfur

Visc @ 40°C

63.58 Contact/Location: ANDREW TURLINGTON - MCQUPP

12


0.046

ppm ASTM D5185m 25

ASTM D445 72.3

Acid Number (AN) mg KOH/g ASTM D974 0.02

cSt



DAIKIN APPLIED Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : WC0798495 Recieved : 01 Jun 2023 5021 HOWERTON WAY SUITE P Lab Number : 05861956 BOWIE, MD Diagnosed : 05 Jun 2023 Unique Number : 10496421 : Jonathan Hester US 20715 Diagnostician Test Package : IND 2 Contact: ANDREW TURLINGTON Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. andrew.turlington@daikinapplied.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (301)735-1440 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (301)735-1838

Contact/Location: ANDREW TURLINGTON - MCQUPP