
**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL ABNORMAL NORMAL** 

## KAESER SX 7.5T 6225671 (S/N 1003)

Component Compressor

RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.	Sample Number		Client Info		KCPA003590	KCP11514	
	Sample Date		Client Info		21 Aug 2023	02 Feb 2019	
	Machine Age	hrs	Client Info		8242	528	
	Oil Age	hrs	Client Info		0	247	
	Filter Age	hrs	Client Info		0	247	
	Oil Changed		Client Info		Changed	Changed	
	Filter Changed		Client Info		Changed	Changed	
	Sample Status				ABNORMAL	ABNORMAL	
WEAR	Iron	ppm	ASTM D5185m	>50	0	2	
VLAII	Chromium	ppm	ASTM D5185m		0	0	
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0	0	
	Titanium	ppm	ASTM D5185m		0	0	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m		<1	<1	
	Lead	ppm	ASTM D5185m		0	<1	
	Copper	ppm	ASTM D5185m		20	2	
	Tin	ppm	ASTM D5185m		<1	0	
	Vanadium	ppm	ASTM D5185m	710	0	0	
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	<1	<1	
	Potassium	ppm	ASTM D5185m	>20	<1	2	
There is a high amount of particulates present in the oil.	Water	%	ASTM D6304	>0.05	0.008	0.013	
	ppm Water	ppm	ASTM D6304	>500	89.5	130	
	Particles >4µm		ASTM D7647		12407	46773	
	Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	
	Particles >14µm		ASTM D7647	>80	<b>4</b> 315	<u> </u>	
	Particles >21µm		ASTM D7647	>20	<b>48</b>	<u> </u>	
	Particles >38µm		ASTM D7647	>4	1	3	
	Particles >71µm		ASTM D7647	>3	0	0	
	Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	<u>22/17</u>	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	LIGHT	VLITE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0	15	
TOIS TONDITION	Boron	ppm	ASTM D5185m	0	0	<1	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm		90	<1	10	
	Molybdenum	ppm	ASTM D5185m		0	0	
	Manganese	ppm	ASTM D5185m		0	<1	
	Magnesium	ppm	ASTM D5185m	100	0	73	
	Calcium	ppm	ASTM D5185m		0	2	
	Phosphorus	ppm	ASTM D5185m		<1	3	
	Zinc	ppm	ASTM D5185m		0	8	
	Sulfur	ppm	ASTM D5185m		19693	23134	
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.35	0.390	
	Visc @ 40°C	cSt	ASTM D445		49.0	43.8	





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: KCPA003590 : 05938312

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 30 Aug 2023 Diagnosed : 31 Aug 2023 : 10628924

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Doug Bogart Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

7501 MILLER DR FREDERICK, CO US 80504

Contact: Service Manager

T: F:

**AQUA HOT**