



# OIL ANALYSIS REPORT

WEAR	<b>NORMAL</b>
CONTAMINATION	<b>ABNORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area  
**STOCK PREP**

Machine Id  
**Compax #1**

Component  
**Gear Reducer**

Fluid  
**SHELL MORLINA S4 B 460 (--- GAL)**

## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. Please note that this is a corrected copy for laboratory data update for water content. ( Customer Sample Comment: Morlina s4 b 460 )

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>PE0000965</b>	---	---
Sample Date		Client Info		<b>29 Aug 2023</b>	---	---
Machine Age	hrs	Client Info		<b>0</b>	---	---
Oil Age	hrs	Client Info		<b>0</b>	---	---
Filter Age	hrs	Client Info		<b>0</b>	---	---
Oil Changed		Client Info		<b>N/A</b>	---	---
Filter Changed		Client Info		<b>N/A</b>	---	---
Sample Status				<b>ABNORMAL</b>	---	---

## WEAR

All component wear rates are normal.

PQ		ASTM D8184		<b>50</b>	---	---
Iron	ppm	ASTM D5185m	>150	<b>30</b>	---	---
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	---	---
Nickel	ppm	ASTM D5185m	>10	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185m		<b>2</b>	---	---
Silver	ppm	ASTM D5185m		<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m	>25	<b>3</b>	---	---
Lead	ppm	ASTM D5185m	>100	<b>0</b>	---	---
Copper	ppm	ASTM D5185m	>50	<b>12</b>	---	---
Tin	ppm	ASTM D5185m	>10	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	---	---
White Metal	scalar	*Visual	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	---	---

## CONTAMINATION









Appearance is hazy. There is a moderate amount of visible silt present in the sample. The water content is negligible.

Silicon	ppm	ASTM D5185m	>50	<b>20</b>	---	---
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	---	---
Water	%	ASTM D6304	>0.1	<b>0.023</b>	---	---
ppm Water	ppm	ASTM D6304	>1000	<b>234.5</b>	---	---
Silt	scalar	*Visual	NONE	<b>▲ MODER</b>	---	---
Debris	scalar	*Visual	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	---	---
Appearance	scalar	*Visual	NORML	<b>● HAZY</b>	---	---
Odor	scalar	*Visual	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	---	---

## FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

Sodium	ppm	ASTM D5185m		<b>0</b>	---	---
Boron	ppm	ASTM D5185m		<b>0</b>	---	---
Barium	ppm	ASTM D5185m		<b>2</b>	---	---
Molybdenum	ppm	ASTM D5185m		<b>0</b>	---	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185m		<b>7</b>	---	---
Calcium	ppm	ASTM D5185m		<b>2381</b>	---	---
Phosphorus	ppm	ASTM D5185m		<b>427</b>	---	---
Zinc	ppm	ASTM D5185m		<b>38</b>	---	---
Sulfur	ppm	ASTM D5185m		<b>3680</b>	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.152</b>	---	---
Visc @ 40°C	cSt	ASTM D445	445	<b>489</b>	---	---



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PE0000965  
**Lab Number** : 05941330  
**Unique Number** : 10631942  
**Test Package** : PLANT ( Additional Tests: ICP, KF, KV40, PQ, PrtCount, SCREEN )

**Received** : 01 Sep 2023  
**Tested** : 12 Sep 2023  
**Diagnosed** : 12 Sep 2023 - Doug Bogart

**MCKINLEY PAPER COMPANY**  
 1902 MARINE DR  
 PORT ANGELES, WA  
 US 98363  
 Contact: JOSHUA HALL  
 joshua.hall@biopappel.com  
 T: (360)457-4474  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)