

## Machine Id KAESER SM 10 AIR CENTER 7969194 (S/N 1142) Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.



All component wear rates are normal.

## CONTAMINATION


Moderate concentration of visible dirt/debris present in the oil.

-----

## FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		KCPA003854	KCP45145	
Sample Date		Client Info		12 Sep 2023	25 May 2022	
Machine Age	hrs	Client Info		11055	4037	
Oil Age	hrs	Client Info		0	4037	
Filter Age	hrs	Client Info		0	4037	
Oil Changed		Client Info		N/A	Changed	
Filter Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	NORMAL	
Iron	ppm	ASTM D5185m	>50	<1	2	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	4	4	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Potassium	ppm	ASTM D5185m	>20	1	0	
Water	%	ASTM D6304	>0.05	0.013	0.008	
ppm Water	ppm	ASTM D6304	>500	132.5	86.3	
Particles >4µm		ASTM D7647	1000		3886	
Particles >6µm		ASTM D7647	>1300		897	
Particles >14µm		ASTM D7647	>80		54	
Particles >21µm		ASTM D7647	>20		13	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647			0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		19/17/13	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE		LIGHT	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
Sodium	ppm	ASTM D5185m		3	6	
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	34	2	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m	-	<1	<1	
Magnesium	ppm	ASTM D5185m	100	59	27	
Calcium	ppm	ASTM D5185m	0	1	<1	
Phosphorus	ppm	ASTM D5185m		1	6	
Zinc	ppm	ASTM D5185m	0	7	9	
Sulfur	ppm	ASTM D5185m	23500	21108	20042	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.38	0.38	
Visc @ 40°C	cSt	ASTM D445	45	45.9	44.4	
	501		10		1.1.1	



PENSKE TRUCK LEASING Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : KCPA003854 Received 15500 E 32ND AVE : 21 Sep 2023 Lab Number : 05957683 AURORA, CO Tested : 22 Sep 2023 Diagnosed : 22 Sep 2023 - Doug Bogart Unique Number : 10658896 US 80011 Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: SERVICE MANAGER Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

jā