WEAR CONTAMINATION **FLUID CONDITION**


ABNORMAL ABNORMAL NORMAL

THYSSEN KRUPP 423826 - AEGIS MERCER

Component Hydraulic System

CITGO NZ (125 GAL)

CIIGO NZ (125 GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
	Sample Number		Client Info		BB0000058		
No corrective action is recommended at this time. We recommend an early resample to monitor this condition.	Sample Date		Client Info		14 Sep 2023		
	Machine Age	yrs	Client Info		5		
	Oil Age	yrs	Client Info		0		
	Filter Age	yrs	Client Info		0		
	Oil Changed		Client Info		N/A		
	Filter Changed		Client Info		N/A		
	Sample Status				ABNORMAL		
WEAR	Iron	ppm	ASTM D5185m	>20	<u> </u>		
	Chromium	ppm	ASTM D5185m	>20	0		
The iron level is abnormal. All other component wear rates are normal.	Nickel	ppm	ASTM D5185m	>20	<1		
	Titanium	ppm	ASTM D5185m		0		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>20	0		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m	>20	<1		
	Tin	ppm	ASTM D5185m		0		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
CONTAMINATION	Silicon	ppm	ASTM D5185m	>15	2		
	Potassium	ppm	ASTM D5185m	>20	2		
There is a high amount of silt (particulates < 14 microns in size) present in the oil.	Water	%	ASTM D6304	>0.05	NEG		
	Particles >4µm		ASTM D7647	>5000	15731		
	Particles >6µm		ASTM D7647		1729		
	Particles >14µm		ASTM D7647		53		
	Particles >21µm		ASTM D7647		9		
	Particles >38µm		ASTM D7647		0		
	Particles >71µm		ASTM D7647		0		
	Oil Cleanliness		ISO 4406 (c)		<u>^</u> 21/18/13		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water		*Visual	>0.05	NEG		
	Linuisilieu Water	Scalai	Visuai	>0.03			
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0		
	Boron	ppm	ASTM D5185m		0		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		<1		
	Magnesium	ppm	ASTM D5185m		0		
	Calcium	ppm	ASTM D5185m		0		
	Phosphorus	ppm	ASTM D5185m		483		
	Zinc	ppm	ASTM D5185m		5		
	Sulfur	ppm	ASTM D5185m		1950		
	Acid Number (AN)	mg KOH/g	ASTM D3163111		0.55		
	Visc @ 40°C	cSt	ASTM D8045 ASTM D445				
	VISC @ 40°C	COL	AS 11VI D443		32.4		





Certificate L2367

Laboratory Sample No.

: BB0000058 Lab Number : 05959769 Unique Number: 10660982 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 25 Sep 2023 **Tested** : 27 Sep 2023

: 27 Sep 2023 - Jonathan Hester Diagnosed

TK Elevator - Kirkland 12530 135th Ave NE Kirkland, WA US 98034

Contact: Chuck Rife chuck.rife@tkelevator.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: