CORROSION CONTAMINANTS COOLANT CONDITION

NORMAL NORMAL NORMAL


[20234836]

Cummins 4700 River Rd 400kw

Component Coolant

CONVENTIONAL COOLANT (30 GAL)

CONVENTIONAL COOLANT (30 GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. The fluid is suitable for further service.	Sample Number		Client Info		DC0029831	DC0021978	
	Sample Date		Client Info		28 Sep 2023	08 Jul 2022	
	Machine Age	yrs	Client Info		0	0	
	Oil Age	yrs	Client Info		0	1	
	Oil Changed		Client Info		Not Changd	Not Changd	
	Sample Status				NORMAL	ABNORMAL	
CORROSION	Iron	ppm	ASTM D6130	>15	5		
All metal levels are normal indicating no corrosion in the cooling system.	Aluminum	ppm	ASTM D6130	>10	<1		
	Copper	ppm	ASTM D6130	>10	<1		
	Lead	ppm	ASTM D6130	>10	6		
	Tin	ppm	ASTM D6130	>10	1		
	Zinc	ppm	ASTM D6130	>10	1		
CONTAMINANTS	Calcium	ppm	ASTM D6130		<1		
There is no indication of any contamination in the coolant.	Chlorine	ppm	ASTM D6130		11		
	Magnesium	ppm	ASTM D6130		5		
	Total Dissolved Solids				239.0	295.0	
	Coolant Appearance		*Visual	Clear	normal	▲ hazy	
COOLANT CONDITION	Specific Gravity		*ASTM D1298		1.064	1.063	
Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.	pН	Scale 0-14	ASTM D1287		8.66	9.03	
	Nitrites	ppm	AP-053:2009		936	1052	
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		47.7	46.8	
	Freezing Point	°F	ASTM D3321		-28	-26	
	Carboxylate				fail	n/a	
	Silicon	ppm	ASTM D6130		71		
	Phosphorus	ppm	ASTM D6130		1		
	Boron	ppm	ASTM D6130		220		
	Molybdenum	ppm	ASTM D6130		51		
	Sodium	ppm	ASTM D6130		1838		
	Potassium	ppm	ASTM D6130		2467		
	Coolant Color		*Visual		Red	Purpl	





Laboratory Sample No.

Lab Number : 05973527 Unique Number: 10685477

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : DC0029831

рΗ

Received **Tested** Diagnosed

: 16 Oct 2023 - Angela Borella Test Package : COOL- (Additional Tests: COOL, ICP)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

JE RICHARDS 4600 HARGROVE DR LANHAM, MD

Nitrites

3000 2800 2600

2000

: 09 Oct 2023

: 12 Oct 2023

US 20706 Contact: E. NOEL enoel@phalconusa.com

T: (240)623-4398 F:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)