

Machine Id KAESER AS 36 1384856 (S/N 1029) Component Compressor Fluid KAESER SIGMA (OEM) FG-460 (--- GAL)

RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

WEAR	

All component wear rates are normal.


CONTAMINATION

There is a moderate amount of particulates present in the oil.

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Test UOM Method Limit/Abn Current Histor	y1 History2
	<i>y</i>
Sample Number Client Info KCPA010704 KCP2	9279 KCP24092
Sample Date Client Info 21 Nov 2023 19 Jul	2021 09 Jun 2020
Machine Age hrs Client Info 38218 35615	5 35011
Oil Age hrs Client Info 0 0	0
Filter Age hrs Client Info 0 0	0
Oil Changed Client Info N/A Changed	aed N/A
Filter Changed Client Info Changed Changed	
Sample Status ATTENTION NORM	
Iron ppm ASTM D5185m >50 8 0	<1
Chromium ppm ASTM D5185m >10 0 0	0
Nickel ppm ASTM D5185m >3 0 0	0
Titanium ppm ASTM D5185m >3 0 0	0
Silver ppm ASTM D5185m >2 0 0	0
Aluminum ppm ASTM D5185m >10 2 0	0
Lead ppm ASTM D5185m >10 0 0	<1
Copper ppm ASTM D5185m >50 6 <1	11
Tin ppm ASTM D5185m >10 0 0	0
Vanadium ppm ASTM D5185m 0 0	0
	NE NONE
	NE NONE
NONE NOIL NOIL NOIL NOIL	NU NONE
Silicon ppm ASTM D5185m >25 0 0	<1
Potassium ppm ASTM D5185m >20 0 0	<1
Water % ASTM D6304 >0.05 0.002 0.0	
ppm Water ppm ASTM D6304 >500 20 54.	
Particles >4µm ASTM D7647 8174 320	
Particles >6µm ASTM D7647 >1300 2242 109	
Particles >14µm ASTM D7647 >80 138 9	43
Particles >21µm ASTM D7647 >20 31 5	16
Particles >38μm ASTM D7647 >4 1 1	2
Particles >71μm ASTM D7647 >3 0 0	0
Oil Cleanliness ISO 4406 (c) >-/17/13 20/18/14 14/	0
	NE NONE
	NE NONE
	NE NONE
	RML NORML
Plana and a second and a second a secon	RML NORML
Emulsified Water scalar *Visual >0.05 NEG NE	G NEG
Sodium ppm ASTM D5185m 1 0	<1
Boron ppm ASTM D5185m 0 2	0
Barium ppm ASTM D5185m 0 0	0
Molybdenum ppm ASTM D5185m O O	0
Manganese ppm ASTM D5185m <1 0	<1
.	5
	5 <1
Phosphorus ppm ASTM D5185m 500 448 453 Zino npm ASTM D5195m 210 27	
Zinc ppm ASTM D5185m 219 27	210
Sulfur ppm ASTM D5185m 1550 170 Acid Number (AN) mg KOH/g ASTM D8045 1.5 1.21 1.4	
ACIO NUMDO (AN) MORTHO ANTINI 80/15 1.5 1.7.7 1.7.7 1.7.7	09 1.387
Acid Number (AN) mg KOH/g ASTM D8045 1.5 1.21 1.4 Visc @ 40°C cSt ASTM D445 46 46.1 46.	3 47.2



. : KCPA010704 :06 Dec 2023 18685 E. PLAZA DR. Sample No. Received : 06026428 :07 Dec 2023 PARKER, CO Lab Number Tested Unique Number : 10776219 : 07 Dec 2023 - Don Baldridge US 80134 Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount) Contact: SERVICE MANAGER Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: F: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER - ORAPAR