



Built for a lifetime™

# OIL ANALYSIS REPORT

WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Machine Id  
**KAESER SK 20 4531417 (S/N 1198)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- QTS)**

## RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>KCPA010908</b>	KCPA002155	KCP55408
Sample Date		Client Info		<b>22 Nov 2023</b>	22 Jun 2023	30 Jan 2023
Machine Age	hrs	Client Info		<b>92064</b>	88994	85565
Oil Age	hrs	Client Info		<b>0</b>	0	3862
Filter Age	hrs	Client Info		<b>0</b>	0	3862
Oil Changed		Client Info		<b>N/A</b>	N/A	Changed
Filter Changed		Client Info		<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	ATTENTION	ABNORMAL

## WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	<b>0</b>	0	4
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>4</b>	3	7
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

## CONTAMINATION











There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Silicon	ppm	ASTM D5185m	>25	<b>0</b>	<1	0
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	1	1
Water	%	ASTM D6304	>0.05	<b>0.015</b>	0.005	▲ 0.059
ppm Water	ppm	ASTM D6304	>500	<b>150</b>	59.4	▲ 590
Particles >4µm		ASTM D7647		<b>1145</b>	4329	---
Particles >6µm		ASTM D7647	>1300	<b>335</b>	● 1477	---
Particles >14µm		ASTM D7647	>80	<b>27</b>	● 92	---
Particles >21µm		ASTM D7647	>20	<b>6</b>	21	---
Particles >38µm		ASTM D7647	>4	<b>1</b>	1	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	---/17/13	<b>17/16/12</b>	● 19/18/14	---
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG	▲ 0.2%

## FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	1	0
Boron	ppm	ASTM D5185m	0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	90	<b>0</b>	1	3
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	100	<b>0</b>	9	2
Calcium	ppm	ASTM D5185m	0	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	0	<b>2</b>	2	3
Zinc	ppm	ASTM D5185m	0	<b>0</b>	3	3
Sulfur	ppm	ASTM D5185m	23500	<b>18391</b>	21498	18629
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.36</b>	0.38	0.38
Visc @ 40°C	cSt	ASTM D445	45	<b>49.5</b>	47.9	49.1



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KCPA010908

Lab Number : 06026436

Unique Number : 10776227

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Received : 06 Dec 2023

Tested : 07 Dec 2023

Diagnosed : 07 Dec 2023 - Don Baldrige

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MACHINING TECHNOLOGY - GLOBAL-TEK

425 S BOWEN ST

LONGMONT, CO

US 80501

Contact: GUY

guy@mtechllc.net

T:

F: