


**WEAR** CONTAMINATION **FLUID CONDITION**  **ABNORMAL** NORMAL **ATTENTION** 

## **DETROIT MV PAUL T**

| RECOMMENDATION  | Test                       | UOM                  | Method                    | Limit/Abn     | Current     | History1    | History2    |
|---|----------------------------|----------------------|---------------------------|---------------|-------------|-------------|-------------|
|   | Sample Number              |                      | Client Info               |               | MW0062746   | MW0036751   | MW0036750   |
| Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. | Sample Date                |                      | Client Info               |               | 03 Jan 2024 |             | 15 Jul 2022 |
|   | Machine Age                | hrs                  | Client Info               |               | 60381       | 500         | 35263       |
|   | Oil Age                    | hrs                  | Client Info               |               | 1500        | 500         | 0           |
|   | Filter Age                 | hrs                  | Client Info               |               | 1500        | 500         | 0           |
|   | Oil Changed                |                      | Client Info               |               | Changed     | Changed     | Changed     |
|   | Filter Changed             |                      | Client Info               |               | Changed     | Changed     | Changed     |
|   | Sample Status              |                      |                           |               | ABNORMAL    | ABNORMAL    | NORMAL      |
| ·   |                            |                      |                           |               |             |             |             |
| WEAR  | Iron                       | ppm                  | ASTM D5185m               |               | 11          | <u></u> 63  | 5           |
| Moderate concentration of visible metal present. All component wear   | Chromium                   | ppm                  | ASTM D5185m               |               | 0           | 1           | <1          |
| rates are normal.   | Nickel                     | ppm                  | ASTM D5185m               | >2            | <1          | <1          | 0           |
|   | Titanium                   | ppm                  | ASTM D5185m               |               | 0           | <1          | 0           |
|   | Silver                     | ppm                  | ASTM D5185m               |               | 0           | 0           | <1          |
|   | Aluminum                   | ppm                  | ASTM D5185m               | >12           | 3           | 4           | 3           |
|   | Lead                       | ppm                  | ASTM D5185m               |               | 2           | <b>4</b> 90 | 1           |
|   | Copper                     | ppm                  | ASTM D5185m               |               | 20          | 2           | 2           |
|   | Tin                        | ppm                  | ASTM D5185m               | >15           | <1          | 2           | <1          |
|   | Vanadium                   | ppm                  | ASTM D5185m               |               | 0           | <1          | 0           |
|   | White Metal                | scalar               | *Visual                   | NONE          | ▲ MODER     | NONE        | NONE        |
|   | Yellow Metal               | scalar               | *Visual                   | NONE          | NONE        | NONE        | NONE        |
| CONTAMINATION   | Silicon                    | ppm                  | ASTM D5185m               | <b>&gt;25</b> | 6           | 6           | 3           |
| CONTAMINATION   | Potassium                  | ppm                  | ASTM D5185m               |               | 0           | <1          | 0           |
| Fuel content negligible. There is no indication of any contamination in the oil.                                | Fuel                       | %                    | ASTM D316311              |               | 0.0         | <1.0        | <1.0        |
|   | Water                      | /0                   | WC Method                 |               | NEG         | NEG         | NEG         |
|   | Glycol                     |                      | WC Method                 | 20.1          | NEG         | NEG         | NEG         |
|   | Soot %                     | %                    | *ASTM D7844               |               | 0           | 0.3         | 0.4         |
|   | Nitration                  | Abs/cm               | *ASTM D7624               | >20           | 4.0         | 13.0        | 10.1        |
|   | Sulfation                  | Abs/.1mm             | *ASTM D7415               |               | 20.1        | 27.6        | 22.9        |
|   | Silt                       | scalar               | *Visual                   | NONE          | NONE        | NONE        | NONE        |
|   | Debris                     | scalar               | *Visual                   | NONE          | NONE        | NONE        | LIGHT       |
|   | Sand/Dirt                  | scalar               | *Visual                   | NONE          | NONE        | NONE        | NONE        |
|   | Appearance                 | scalar               | *Visual                   | NORML         | NORML       | NORML       | NORML       |
|   | Odor                       | scalar               | *Visual                   | NORML         | NORML       | NORML       | NORML       |
|   | <b>Emulsified Water</b>    | scalar               | *Visual                   | >0.1          | NEG         | NEG         | NEG         |
|   |                            |                      |                           |               |             |             |             |
| FLUID CONDITION   | Sodium                     | ppm                  | ASTM D5185m               |               | 2           | 2           | 2           |
| The oil viscosity is lower than normal. The BN result indicates that  | Boron                      | ppm                  | ASTM D5185m               |               | 301         | 202         | 376         |
| there is suitable alkalinity remaining in the oil. Confirm oil type.  | Barium                     | ppm                  |                           |               | 0           | 0           | 4           |
|   | Molybdenum                 | ppm                  | ASTM D5185m               | 100           | 106         | 117         | 114         |
|   | Manganese                  | ppm                  | ASTM D5185m               |               | <1          | <1          | <1          |
|   | Magnesium                  | ppm                  | ASTM D5185m               |               | 645         | 748         | 673         |
|   | Calcium                    | ppm                  | ASTM D5185m               |               | 1320        | 1568        | 1484        |
|   | Phosphorus                 | ppm                  | ASTM D5185m               |               | 766         | 730         | 683         |
|   | Zinc                       | ppm                  | ASTM D5185m               |               | 878         | 946         | 862         |
|   | Sulfur                     | ppm                  | ASTM D5185m               |               | 2528        | 2538        | 2879        |
|   | Oxidation Base Number (BN) | Abs/.1mm<br>mg KOH/g | *ASTM D7414<br>ASTM D2896 |               | 12.9<br>7.8 | 29.1<br>8.2 | 19.6<br>9.0 |
|   |                            |                      |                           |               |             |             |             |







Certificate L2367

Laboratory

Sample No. Lab Number **Unique Number** 

: 06054659 : 10820608

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : MW0062746 Recieved : 08 Jan 2024

Diagnosed : 12 Jan 2024 Diagnostician : Jonathan Hester

Test Package : MAR 2 ( Additional Tests: FuelDilution, PercentFuel ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



50 E RIVERCENTER BLVD, SUITE 1180 COVINGTON, KY

US 41011

Contact: DAVID WESTRICH dwestrich@carlislebray.com

T: (812)290-4063 F: (859)655-7504