
**WEAR** CONTAMINATION **FLUID CONDITION** 

**NORMAL ABNORMAL NORMAL** 

## MATTEI 10022314-2022 (S/N 553)

Component Compressor

ROTOROIL 8000 ( QTS)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. Resample at the next service interval to monitor.	Sample Number		Client Info		AN37195	AN38743	
	Sample Date		Client Info		18 Dec 2023	22 Dec 2022	
	Machine Age	hrs	Client Info		416	0	
	Oil Age	hrs	Client Info		0	7	
	Filter Age	hrs	Client Info		0	0	
	Oil Changed		Client Info		Changed	N/A	
	Filter Changed		Client Info		N/A	N/A	
	Sample Status				ABNORMAL	SEVERE	
WEAR	Iron	ppm	ASTM D5185m	>50	7	14	
All component wear rates are normal.	Chromium	ppm	ASTM D5185m	>10	0	0	
	Nickel	ppm	ASTM D5185m		0	0	
	Titanium	ppm	ASTM D5185m		0	0	
	Silver	ppm	ASTM D5185m		0	0	
	Aluminum	ppm	ASTM D5185m	>25	10	7	
	Lead	ppm	ASTM D5185m		0	0	
	Copper	ppm	ASTM D5185m	>50	0	<1	
	Tin	ppm	ASTM D5185m	>15	2	2	
	Vanadium	ppm	ASTM D5185m		0	0	
	White Metal	scalar	*Visual	NONE	LIGHT	LIGHT	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
CONTAMINATION  Elemental level of silicon (Si) above normal.	Silicon	ppm	ASTM D5185m	>25	<u>^</u> 50	136	
	Potassium	ppm	ASTM D5185m		0	1	
	Water	%	ASTM D6304	>0.1	0.033	0.080	
	ppm Water	ppm	ASTM D6304	>1000	331	808.7	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Appearance	scalar	*Visual	NORML	NORML	NORML	
	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0	12	
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Boron	ppm	ASTM D5185m		0	0	
	Barium	ppm	ASTM D5185m		0	0	
	Molybdenum	ppm	ASTM D5185m		0	0	
	Manganese	ppm	ASTM D5185m		0	<1	
	Magnesium	ppm	ASTM D5185m		0	2	
	Calcium	ppm	ASTM D5185m		0	<1	
	Phosphorus	ppm	ASTM D5185m	884	951	1124	
	Zinc	ppm	ASTM D5185m		0	3	
	Sulfur	ppm	ASTM D5185m		161	64	
	Acid Number (AN)	mg KOH/g	ASTM D8045	0.1	0.28	0.05	
	Visc @ 40°C	cSt	ASTM D445	87 69	74.7	67.9	







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: AN37195 : 06055934 : 10821883 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 09 Jan 2024 Diagnosed : 11 Jan 2024 Diagnostician

: Jonathan Hester

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MATTEI COMPRESSORS--OEM

9635 LIBERTY ROAD, SUITE E RANDALLSTOWN, MD

US 21133 Contact: MARTY WARD

jward@matteicomp.com T: (410)521-7020 F: (410)521-7024