



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Area  
**EILEEN BIGELOW**  
Machine Id  
**[EILEEN BIGELOW] 002 588445-2**  
Component  
**Center Main Engine**  
Fluid  
**CHEVRON DELO 710 LE (300 GAL)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>MW06056004</b>	MW06055521	MW05980639
Sample Date		Client Info		<b>01 Jan 2024</b>	01 Dec 2023	01 Oct 2023
Machine Age	hrs	Client Info		<b>0</b>	4257	2959
Oil Age	hrs	Client Info		<b>0</b>	4257	2959
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>N/A</b>	N/A	N/A
Filter Changed		Client Info		<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>75	<b>26</b>	21	23
Chromium	ppm	ASTM D5185m	>8	<b>2</b>	2	2
Nickel	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	>3	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>15	<b>2</b>	2	2
Lead	ppm	ASTM D5185m	>18	<b>9</b>	7	10
Copper	ppm	ASTM D5185m	>80	<b>24</b>	21	17
Tin	ppm	ASTM D5185m	>14	<b>12</b>	10	11
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

**CONTAMINATION**







There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>20	<b>6</b>	5	6
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	3
Fuel		WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	*ASTM D7844	>3	<b>0.9</b>	0.9	0.7
Nitration	Abs/cm	*ASTM D7624	>20	<b>8.9</b>	8.7	8.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.9</b>	17.2	16.5
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m	>75	<b>1</b>	2	1
Boron	ppm	ASTM D5185m		<b>37</b>	37	38
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>49</b>	44	47
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	1	<1
Magnesium	ppm	ASTM D5185m		<b>33</b>	12	0
Calcium	ppm	ASTM D5185m		<b>3594</b>	3485	3702
Phosphorus	ppm	ASTM D5185m		<b>18</b>	4	0
Zinc	ppm	ASTM D5185m	10	<b>24</b>	0	0
Sulfur	ppm	ASTM D5185m		<b>2402</b>	2268	2636
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>8.7</b>	8.6	8.0
Base Number (BN)	mg KOH/g	ASTM D2896	9.2	<b>8.97</b>	9.68	8.81
Visc @ 100°C	cSt	ASTM D445	15.5	<b>15.1</b>	15.2	15.1



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : MW06056004 **Received** : 09 Jan 2024  
**Lab Number** : 06056004 **Diagnosed** : 11 Jan 2024  
**Unique Number** : 10821953 **Diagnostician** : Wes Davis  
**Test Package** : MAR 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**INGRAM BARGE**  
 900 S 3RD ST  
 PADUCAH, KY  
 US 42003

Contact: TONY HUCKABEE  
 tony.huckabee@ingrambarge.com  
 T: (270)415-4467  
 F: (615)695-3697