



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Area
PALLUBE 32 [158849]
 Machine Id
PALATEK SP16-100 1507220001 - GVS FILTRATION
 Component
Compressor

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		UCZ06056828	UCZ05810505	UCZ05707247
Sample Date		Client Info		27 Nov 2023	14 Mar 2023	17 Nov 2022
Machine Age	hrs	Client Info		44442	65541	62730
Oil Age	hrs	Client Info		1538	2811	8448
Filter Age	hrs	Client Info		1538	2811	3212
Oil Changed		Client Info		Not Changed	Not Changed	Changed
Filter Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	0	<1	<1
Lead	ppm	ASTM D5185m	>65	0	0	<1
Copper	ppm	ASTM D5185m	>65	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	<1	1
Vanadium	ppm	ASTM D5185m		<1	0	<1
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION







There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>35	<1	1	1
Potassium	ppm	ASTM D5185m	>20	3	3	3
Water		WC Method	>0.1	NEG	NEG	NEG
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		44	31	52
Boron	ppm	ASTM D5185m	1	0	0	0
Barium	ppm	ASTM D5185m	730	90	66	66
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0.0	0	<1	0
Magnesium	ppm	ASTM D5185m	0	0	1	<1
Calcium	ppm	ASTM D5185m	0	<1	2	0
Phosphorus	ppm	ASTM D5185m	0	5	8	26
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	590	590	341	210
Acid Number (AN)	mg KOH/g	ASTM D8045	0.14	0.19	0.26	0.31
Visc @ 40°C	cSt	ASTM D445	42.8	42.5	42.6	44.8



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCZ06056828 **Received** : 10 Jan 2024
Lab Number : 06056828 **Diagnosed** : 11 Jan 2024
Unique Number : 10822777 **Diagnostician** : Don Baldrige
Test Package : IND 2

ZORN COMP & EQUIPMENT INC - EAU CLAIRE
 2218-D TRUAX BLVD
 EAU CLAIRE, WI
 US 54703
 Contact: BILL MESTELLE
 bill.mestelle@zornair.com
 T: (715)830-5292
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)