



OIL ANALYSIS REPORT

WEAR	NORMAL
CONTAMINATION	NORMAL
FLUID CONDITION	NORMAL

Machine Id
AW 46
Component
New (Unused) Oil
Fluid
{not provided} (--- QTS)

RECOMMENDATION

This is a baseline read-out on the submitted sample.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0031127	DC0031128	DC0031095
Sample Date		Client Info		29 Dec 2023	27 Dec 2023	14 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Filter Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Filter Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

WEAR











Iron	ppm	ASTM D5185m		0	0	0
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		<1	0	0
Lead	ppm	ASTM D5185m		1	<1	0
Copper	ppm	ASTM D5185m		<1	<1	0
Tin	ppm	ASTM D5185m		1	1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION

Silicon	ppm	ASTM D5185m		<1	<1	<1
Potassium	ppm	ASTM D5185m	>20	1	1	0
Water		WC Method		NEG	NEG	NEG
Particles >4µm		ASTM D7647	>5000	529	497	404
Particles >6µm		ASTM D7647	>1300	141	126	86
Particles >14µm		ASTM D7647	>160	10	14	5
Particles >21µm		ASTM D7647	>40	3	3	2
Particles >38µm		ASTM D7647	>10	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/14/10	16/14/11	16/14/10
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual		NEG	NEG	NEG

FLUID CONDITION

Sodium	ppm	ASTM D5185m		2	2	2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		107	105	99
Calcium	ppm	ASTM D5185m		79	72	85
Phosphorus	ppm	ASTM D5185m		346	332	339
Zinc	ppm	ASTM D5185m		428	414	410
Sulfur	ppm	ASTM D5185m		5894	5726	5632
Acid Number (AN)	mg KOH/g	ASTM D8045		0.32	0.34	0.48
Visc @ 40°C	cSt	ASTM D445		45.06	43.65	42.4
Visc @ 100°C	cSt	ASTM D445		6.94	6.86	6.72
Viscosity Index (VI)	Scale	ASTM D2270		110	113	112



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0031127 **Received** : 10 Jan 2024
Lab Number : 06057103 **Diagnosed** : 12 Jan 2024
Unique Number : 10823052 **Diagnostician** : Jonathan Hester

THE UNITED OIL COMPANY - OPERATIONS
 4405 E. BALTIMORE ST
 BALTIMORE, MD
 US 21224

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: (410)327-7695