



COOLANT REPORT

CORROSION	NORMAL
CONTAMINANTS	NORMAL
COOLANT CONDITION	NORMAL

Machine Id
20240
 Component
Coolant
 Fluid
{not provided} (--- GAL)

RECOMMENDATION

No corrective action is recommended at this time. The fluid is suitable for further service.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		DC0031719	DC0012734	---
Sample Date		Client Info		04 Jan 2024	01 Dec 2022	---
Machine Age	hrs	Client Info		8570	0	---
Oil Age	hrs	Client Info		0	0	---
Oil Changed		Client Info		Not Changd	Not Changd	---
Sample Status				NORMAL	NORMAL	---








CORROSION

Total Dissolved Solids				436.5	393.0	---
Coolant Appearance		*Visual	Clear	normal	normal	---

CONTAMINANTS

There is no indication of any contamination in the coolant.

Specific Gravity		*ASTM D1298		1.074	1.068	---
pH	Scale 0-14	ASTM D1287		8.40	8.47	---
Nitrites	ppm	AP-053:2009		NT	0	---
Reserve Alkalinity	Scale 0-20	*ASTM D1121		---	---	---
Percentage Glycol	%	ASTM D3321		55.5	50.5	---
Freezing Point	°F	ASTM D3321		-47	-35	---
Carboxylate				fail	fail	---
Coolant Color		*Visual		Red	Red	---



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0031719 **Received** : 10 Jan 2024
Lab Number : 06057145 **Diagnosed** : 12 Jan 2024
Unique Number : 10823094 **Diagnostician** : Jonathan Hester
Test Package : COOL- (Additional Tests: COOL)

FRANCIS O DAY
 14900 SOUTHLAWN LN
 ROCKVILLE, MD
 US 20850
 Contact: JAMIE FORESTER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: