
CORROSION CONTAMINANTS COOLANT CONDITION


NORMAL NORMAL NORMAL

Machine Id 60500 Component

Component Coolant

{not provided} (GAL)					.,		
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
No corrective action is recommended at this time. The fluid is suitable for further service.	Sample Number		Client Info		DC0032992	DC0025090	DC0024280
	Sample Date		Client Info		29 Dec 2023	07 Nov 2022	07 Nov 2022
	Machine Age	hrs	Client Info		12704	12667	12668
	Oil Age	hrs	Client Info		0	0	0
	Oil Changed		Client Info		N/A	Not Changd	N/A
	Sample Status				NORMAL	NORMAL	NORMAL
CORROSION	RROSION Total Dissolved Solids				465.5	356.5	470.5
	Coolant Appearance		*Visual	Clear	normal	normal	normal
CONTAMINANTS	Specific Gravity		*ASTM D1298		1.067	1.067	1.067
There is no indication of any contamination in the coolant.	рН	Scale 0-14	ASTM D1287		9.04	8.94	9.02
	Nitrites	ppm	AP-053:2009		NT	NT	NT
	Reserve Alkalinity	Scale 0-20	*ASTM D1121				
	Percentage Glycol	%	ASTM D3321		49.2	49.3	49.4
	Freezing Point	°F	ASTM D3321		-33	-33	-33
	Carboxylate				fail	pass	pass
	Coolant Color		*Visual		Red	Red	Red







Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10823114

: DC0032992 : 06057165

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 10 Jan 2024 Diagnosed

Test Package : COOL- (Additional Tests: COOL)

: 12 Jan 2024 Diagnostician : Jonathan Hester 14900 SOUTHLAWN LN

US 20850 Contact: JAMIE FORESTER

FRANCIS O DAY

ROCKVILLE, MD

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: