



WEAR	<b>NORMAL</b>
CONTAMINATION	<b>NORMAL</b>
FLUID CONDITION	<b>NORMAL</b>

Machine Id  
**PRAIRIE MOON**

Component  
**Starboard Genset**

Fluid  
**PETRO CANADA DURON MARINE SAE 40 (3 GAL)**

**RECOMMENDATION**

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		<b>MWM695476</b>	MWM667130	MWM667129
Sample Date		Client Info		<b>05 Jan 2024</b>	08 Nov 2023	18 Sep 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>800</b>	600	600
Filter Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed		Client Info		<b>Changed</b>	Changed	Changed
Filter Changed		Client Info		<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

**WEAR**

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	<b>2</b>	3	2
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>2	<b>1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>12	<b>2</b>	1	<1
Lead	ppm	ASTM D5185m	>17	<b>2</b>	<1	0
Copper	ppm	ASTM D5185m	>70	<b>&lt;1</b>	0	0
Tin	ppm	ASTM D5185m	>15	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE

**CONTAMINATION**







There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>25	<b>2</b>	2	4
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	1	<1
Fuel		WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water		WC Method	>0.1	<b>NEG</b>	NEG	NEG
Glycol		WC Method		<b>NEG</b>	NEG	NEG
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.2</b>	5.1	4.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>15.4</b>	14.9	13.7
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG

**FLUID CONDITION**

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Boron	ppm	ASTM D5185m	1.0	<b>0</b>	4	2
Barium	ppm	ASTM D5185m	1.0	<b>0</b>	<1	0
Molybdenum	ppm	ASTM D5185m	1.0	<b>3</b>	2	2
Manganese	ppm	ASTM D5185m	1	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	15	<b>943</b>	895	879
Calcium	ppm	ASTM D5185m	2540	<b>1039</b>	1050	1061
Phosphorus	ppm	ASTM D5185m	1000	<b>1109</b>	1135	1104
Zinc	ppm	ASTM D5185m	1110	<b>1423</b>	1326	1303
Sulfur	ppm	ASTM D5185m	3700	<b>3217</b>	3059	3017
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>9.2</b>	8.9	7.8
Base Number (BN)	mg KOH/g	ASTM D2896	7.9	<b>6.5</b>	6.7	6.7
Visc @ 100°C	cSt	ASTM D445	14.6	<b>13.8</b>	13.8	13.6



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : MWM695476 **Received** : 12 Jan 2024  
**Lab Number** : 06059088 **Diagnosed** : 12 Jan 2024  
**Unique Number** : 10830470 **Diagnostician** : Wes Davis  
**Test Package** : MAR 2

**AMERICAN RIVER TRANS. CO. PEORIA**  
 534 WESLEY RD  
 CREVECOEUR, IL  
 US 61610  
 Contact: STEVE BUCCO

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (309)360-3931  
 F: (309)694-7030