WEAR CONTAMINATION **FLUID CONDITION**

NORMAL ABNORMAL NORMAL

COMPRESSOR 3 (S/N 18879)

Component Compressor

NGERSOLL-RAND TURBOBLEND 46 (50 GAL	/						
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
We recommend you comise the filters as this second of said	Sample Number		Client Info		CCSI2008800		
We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.	Sample Date		Client Info		04 Jan 2024		
	Machine Age	hrs	Client Info		55749		
	Oil Age	hrs	Client Info		0		
	Filter Age	hrs	Client Info		0		
	Oil Changed		Client Info		Not Changd		
	Filter Changed		Client Info		N/A		
	Sample Status				ABNORMAL		
/EAR	Iron	ppm	ASTM D5185m	>50	<1		
	Chromium	ppm	ASTM D5185m	>10	<1		
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0		
	Titanium	ppm	ASTM D5185m		<1		
	Silver	ppm	ASTM D5185m		0		
	Aluminum	ppm	ASTM D5185m	>25	2		
	Lead	ppm	ASTM D5185m		0		
	Copper	ppm	ASTM D5185m		<1		
	Tin	ppm	ASTM D5185m		<1		
	Vanadium	ppm	ASTM D5185m		0		
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
ONTAMINATION	Silicon	nnm	ASTM D5185m	\ 25	<1		
ONTAMINATION	Potassium	ppm	ASTM D5185m		1		
There is a high amount of particulates present in the oil.	Water	ppm	WC Method		NEG		
			ASTM D7647	>0.1			
	Particles >4µm Particles >6µm		ASTM D7647		▲ 83120 ▲ 27980		
	Particles >6µm		ASTM D7647		▲ 27980 ▲ 2583		
	Particles >21µm		ASTM D7647	>80	▲ 607		
			ASTM D7647		▲ 26		
	Particles >38μm Particles >71μm		ASTM D7647				
					1		
	Oil Cleanliness Silt	acalar	ISO 4406 (c)		A 24/22/19		
		scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
	Appearance	scalar	*Visual	NORML	NORML		
	Odor	scalar	*Visual	NORML	NORML		
<u></u>	Emulsified Water	scalar	*Visual	>0.1	NEG		
LUID CONDITION	Sodium	ppm	ASTM D5185m		0		
	Boron	ppm	ASTM D5185m		0		
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.	Barium	ppm	ASTM D5185m		0		
	Molybdenum	ppm	ASTM D5185m		0		
	Manganese	ppm	ASTM D5185m		0		
	Magnesium	ppm	ASTM D5185m		0		
	Calcium	ppm	ASTM D5185m		1		
	Phosphorus	ppm	ASTM D5185m		39		
	Zinc	ppm	ASTM D5185m		0		
	Sulfur	ppm	ASTM D5185m		0		
	Acid Number (AN)	mg KOH/g	ASTM D8045		0.12		
	Visc @ 40°C	cSt	ASTM D445		47.4		





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: CCSI2008800 : 06061916 : 10833298

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 16 Jan 2024 Diagnosed : 18 Jan 2024 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

BALL METAL BEVERAGE PACKAGING

1001 N FM 3083 E CONROE, TX US 77303 Contact: LES WILLIAMS les.williams@ball.com T: (936)520-9384

Contact/Location: LES WILLIAMS - BALCON