

Area
(TX263232)
 Machine Id
3691C
 Component
Natural Gas Engine
 Fluid
PETRO CANADA DURON GEO LD 15W40 (7 GAL)

RECOMMENDATION

Resample at the next service interval to monitor.

Test	UOM	Method	Limit/Abn	Current	History1	History2
Sample Number		Client Info		GFL0023768	GFL0052190	GFL0044044
Sample Date		Client Info		18 Jan 2024	20 Sep 2022	19 May 2022
Machine Age	mls	Client Info		146312	146312	146312
Oil Age	mls	Client Info		146312	18592	17790
Filter Age	mls	Client Info		0	1468	666
Oil Changed		Client Info		N/A	Changed	Not Changd
Filter Changed		Client Info		N/A	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL

WEAR

All component wear rates are normal.

Iron	ppm	ASTM D5185m	>50	10	20	7
Chromium	ppm	ASTM D5185m	>4	<1	3	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	<1
Aluminum	ppm	ASTM D5185m	>9	1	2	2
Lead	ppm	ASTM D5185m	>30	0	12	1
Copper	ppm	ASTM D5185m	>35	2	1	<1
Tin	ppm	ASTM D5185m	>4	<1	2	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE

CONTAMINATION











There is no indication of any contamination in the oil.

Silicon	ppm	ASTM D5185m	>+100	4	4	3
Potassium	ppm	ASTM D5185m	>20	0	2	0
Water		WC Method	>0.1	NEG	NEG	NEG
Soot %	%	*ASTM D7844		0	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	10.0	15.0	11.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.9	31.1	21.6
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG

FLUID CONDITION

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

Sodium	ppm	ASTM D5185m		4	10	6
Boron	ppm	ASTM D5185m	50	17	9	<1
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	55	76	62
Manganese	ppm	ASTM D5185m	0	<1	1	<1
Magnesium	ppm	ASTM D5185m	560	663	641	559
Calcium	ppm	ASTM D5185m	1510	1710	1884	1608
Phosphorus	ppm	ASTM D5185m	780	885	847	648
Zinc	ppm	ASTM D5185m	870	1121	1075	917
Sulfur	ppm	ASTM D5185m	2040	2784	3040	2322
Oxidation	Abs/.1mm	*ASTM D7414	>25	17.7	28.5	18.3
Base Number (BN)	mg KOH/g	ASTM D2896	10.2	6.2	3.8	4.6
Visc @ 100°C	cSt	ASTM D445	15.1	15.0	15.5	15.1



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : GFL0023768 **Received** : 19 Jan 2024
Lab Number : 06065381 **Diagnosed** : 22 Jan 2024
Unique Number : 10836763 **Diagnostician** : Wes Davis
Test Package : MOB1+

GFL Environmental - 045 - Tidewater
 3821 Cook Blvd.
 Chesapeake, VA
 US 23323
 Contact: ELVIN RODRIGUEZ
 elvinrodriguez@gflenv.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)