WEAR CONTAMINATION FLUID CONDITION


NORMAL ABNORMAL ABNORMAL

Machine Id

QUINCY 970264C - FORTERRA PIPE

Compressor							
Fluid							
QUINCY QUINSYN (GAL)							
RECOMMENDATION	Test	UOM	Method	Limit/Abn	Current	History1	History2
The oil is near the end of it's useful service life, recommend schedule an oil change. We recommend you service the filters on this	Sample Number		Client Info		QUC0000632	QUC0000522	QUC0000393
	Sample Date		Client Info		02 Jan 2024	20 Oct 2023	04 Apr 2023
	Machine Age	hrs	Client Info		0	60112	60063
component. We recommend an early resample to monitor this	Oil Age	hrs	Client Info		0	0	0
condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.	Filter Age	hrs	Client Info		0	0	0
concentration of particles present in this sample.	Oil Changed		Client Info		N/A	Not Changd	Not Changd
	Filter Changed		Client Info		N/A	Changed	Changed
	Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR	Iron	ppm	ASTM D5185m	>50	4	2	2
WEAIT	Chromium	ppm	ASTM D5185m		<1	0	0
All component wear rates are normal.	Nickel	ppm	ASTM D5185m		0	0	0
	Titanium	ppm	ASTM D5185m		<1	<1	0
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>25	2	1	0
	Lead	ppm	ASTM D5185m		<1	0	0
	Copper	ppm	ASTM D5185m		<1	0	<1
	Tin	ppm	ASTM D5185m	>15	<1	0	0
	Vanadium	ppm	ASTM D5185m	NONE	0	0	0
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
CONTAMINATION	Silicon	ppm	ASTM D5185m	>25	0	4	<1
CONTAININATION	Potassium	ppm	ASTM D5185m		2	<1	<1
There is a light concentration of water present in the oil. There is a high	Water	%	ASTM D6304	>0.1	△ 0.106	0.004	0.009
amount of visible silt present in the sample.	ppm Water	ppm	ASTM D6304	>1000	1069	48.5	92.1
	Particles >4µm		ASTM D7647	>10000		<u> </u>	<u>▲</u> 32564
	Particles >6µm		ASTM D7647			<u> </u>	<u>▲</u> 6959
	Particles >14μm		ASTM D7647			<u>489</u>	231
	Particles >21µm		ASTM D7647			72	53
	Particles >38µm		ASTM D7647			4	5
	Particles >71µm Oil Cleanliness		ASTM D7647			0	22/20/15
	Silt	scalar	ISO 4406 (c) *Visual	>20/18/15 NONE	 A HEAVY	25/23/16 NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
	Odor		*Visual	NORML	NORML	NORML	NORML
	Emulsified Water		*Visual	>0.1	NEG	NEG	NEG
FLUID CONDITION							
FLUID CONDITION	Sodium	ppm	ASTM D5185m		0	4	1
The AN level is at the top-end of the recommended limit.	Boron	ppm	ASTM D5185m		0	0	0
The first level to at the top one of the recommended with.	Barium Molybdenum	ppm	ASTM D5185m ASTM D5185m		0 <1	0	0 <1
	Manganese	ppm	ASTM D5185m		0	<1	0
	Magnesium	ppm	ASTM D5185m		0	<1	<1
	Calcium	ppm	ASTM D5185m		0	3	<1
	Phosphorus	ppm	ASTM D5185m		55	133	142
	Zinc	ppm	ASTM D5185m		0	6	16
	Sulfur	ppm	ASTM D5185m		1057	1029	1086
	Acid Number (AN)	mg KOH/g	ASTM D8045		<u> </u>	0.25	0.34
	Visc @ 40°C	cSt	ASTM D445		45.2	44.5	44.4
	Visc @ 100°C	cSt	ASTM D445		7.9	7.8	7.8
	Viscosity Index (VI)	Scale	ASTM D2270	132	146	145	146

Contact/Location: SEAN ? - QUAALV







Certificate L2367

Laboratory Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 06074700 Unique Number : 10856791

: QUC0000632

Recieved Diagnosed

: 30 Jan 2024 : 01 Feb 2024 Diagnostician : Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **QUALITY COMPRESSOR**

4428 CR 616 ALVARADO, TX US 76009 Contact: SEAN

SEAN@QCOMPRESSOR.COM

T: (817)822-1333

F: